

**From:** Gerry Proteau <gproteau@wireservices.ca>  
**Sent:** Wednesday, October 24, 2012 12:49 PM  
**To:** Paul Wilson <plwilson@mhi.ca>  
**Subject:** RE: Nalcor Report  
**Attach:** Final MHI DG3 report - GP.docx; Exhibit 92 Summary.pdf

---

Paul, I've made a few more edits based on your questions –see attached. I think Nalcor can live with our opinion on the reliability statements. I've attached some of exhibit 92 again which refers to the reliability return periods and loads expected.

Gerry

---

**From:** Paul Wilson  
**Sent:** Wednesday, October 24, 2012 1:19 PM  
**To:** Gerry Proteau  
**Subject:** RE: Nalcor Report

Hi Gerry, I went through your new wording and made some minor revisions, and asked a couple of questions in the comments. Please see the document and send me another update ASAP.

Nalcor is not going to send us anything as it is too late in the game. The wording revisions will have to do.

Paul Wilson

---

**From:** Gerry Proteau  
**Sent:** October-24-12 10:55 AM  
**To:** Paul Wilson  
**Subject:** Nalcor Report

Paul, some draft language revising the Nalcor report. What I'm trying to say in my revisions is that we support Nalcor's diligent work in all the past weather studies, and there has been a lot of good work, but we stand firm in our recommendation that the entire line be designed to 1:150 in accordance to CSA guidelines –and let Nalcor fight their future battle on why some of the line is 1:50 and others not.

You can call me anytime in the evening Wpg time, or during working hours if you are awake.

Thanks,

Gerry

**G. A. (Gerald) Proteau P. Eng.**  
**Senior Project Development Engineer**  
W.I.R.E. Services | Manitoba Hydro International  
211 Commerce Drive | Winnipeg | R3P 1A3 | Canada  
Ph 204-480-5803 | Mob 204-██████-395 | Fax 204-480-5107  
Email [gproteau@wireservices.ca](mailto:gproteau@wireservices.ca) | Web [www.wireservices.ca](http://www.wireservices.ca)