


CONSUMER ADVOCATE FOR NEFWOUNDLAND AND LABRADOR TWO GENERATION EXPANSION OPTIONS

HIGH LEVEL REVIEW REPORT




PREPARED FOR

Consumer Advocate for Newfoundland and Labrador
c/o O'Dea, Earle Law Offices
323 Duckworth Street
St John's, NL A1X 5X4

PREPARED BY

Knight Piésold Ltd.
Suite 1400 – 750 West Pender Street
Vancouver, BC V6C 2T8



VA103-365/2-1
Rev A
November 2, 2011

Knight Piésold
CONSULTING

ISO 9001, ISO 14001
OHSAS 18001

**CONSUMER ADVOCATE FOR
NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION OPTIONS**

**HIGH LEVEL REVIEW REPORT
(REF. NO. VA1103-365/2-1)**

Rev	Description	Date	Approved
A	Issued in Draft (Prior to Manitoba Hydro Review)	November 2, 2011	SRM

Knight Piésold Ltd.

Suite 1400
750 West Pender Street
Vancouver, British Columbia Canada V6C 2T8
Telephone: (604) 685-0543
Facsimile: (604) 685-0147
www.knightpiesold.com

Knight Piésold
CONSULTING



**CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION OPTIONS**

**HIGH LEVEL REVIEW REPORT
(REF. NO. VA103-365/2-1)**

EXECUTIVE SUMMARY

The Government of the Province of Newfoundland and Labrador is proposing to develop the Lower Churchill hydro resource as the preferred long-term power supply for the island of Newfoundland. The Board of Commissioners of Public Utilities is an independent, quasi-judicial tribunal responsible for, amongst other things, the regulation of and general supervision of public utilities in the Province.

The government has made a reference to the Board, in which it is stated: *"In the Energy Plan, 2007, Government committed to the development of the Lower Churchill hydro resource. It has been determined that the least-cost option for the supply of power to the Island interconnected system over the period of 2011-2067 is the development of the Muskrat Falls generation facility and the Labrador-Island Link transmission line (the "Projects")...as compared to the isolated Island development scenario (the "Isolated Island Option")...both of which shall be outlined further in a submission made by Nalcor Energy ("Nalcor") to the Board of Commissioners of Public Utilities) the ("Board"), and the Board has been directed to: "review and report to Government on whether the Projects represent the least-cost option for the supply of power to Island Interconnected Customers over the period of 2011-2067, as compared to the Isolated Island Option, this being the "Reference Question".*

Providing an answer to the "Reference Question" is the focus of this High Level Review Report.

Knight Piésold Ltd. has performed this high level review of the information provided by Nalcor on behalf of the Consumer Advocate of Newfoundland and Labrador. The information provided to date by Nalcor, has been delivered in a piecemeal fashion, with a number of key documents still being withheld from the Public by Nalcor, as they are considered "Confidential". Due to the lack of available detailed costing information, Knight Piésold has completed this High Level Review Report based on its own recent and relevant experience with regards to project costs associated with each of the proposed development options.

This review is limited to the comparison of the Two Generations Options presented to the Board by Nalcor as follows:

- Interconnected Island Option:
 - 824 MW Muskrat Falls Hydro (MF) plus 50 MW CT on Island (Generation).
 - 900 MW HVDC Labrador Island Link (LIL) (Transmission).
- Isolated Island Option:
 - 25 MW Wind.
 - 36 MW Island Pond, 23 MW Portland Creek and 18 MW Round Pond Hydro.
 - Holyrood Upgrades.
 - 170 MW CCGT, and incremental 50 MW CT additions.
 - Holyrood Replacement post 2030 with additional Thermal Generation.



Based on the information available at the time of writing this report, Knight Piesold is in general agreement with Nalcor assessment that the Interconnected Island Option represents the least-cost option for the supply of power to Island Interconnected Customers over the period of 2011-2067. However, it should be noted that the projections on fuel price increases over the next 50 years have a significant impact on these findings, and if the fuel prices do not increase at the rates projected, then the difference between the two generations options is significantly reduced.

Knight Piésold has further found that:

- The demand projections methodologies presented are reasonable, and have been accepted for the analysis presented in this report.
- Demand side management results were not included and could have a measurable impact, its bearing on the overall supply selection needs to be demonstrated. (The Navigant Report indicated it did not have an impact.)
- The Isolated Island Option does not integrate as much wind or small hydro into consideration as was possible; however the development of these renewable resources would not alleviate the requirement for the development of firm thermal resources in the future under the Isolated Island Option. The projected ratio of Island renewable resources to overall oil based thermal resources is insufficient to compete with the interconnected island option.
- Nalcor and Navigant excluded natural gas generation in the generation expansion alternatives on the basis that natural gas was not yet available on the island and there was no firm plans to bring natural gas to the island, however natural gas within a larger development plan of Newfoundland and Labrador at current projected market rates could be very cost competitive with MF and the LIL.
- The targeted online date of the Isolated Island Options is suspect as Portland Creek project appears more financially attractive than the Island Pond and a Wind Power Project.
- The cost of the Churchill Falls-Muskrat Falls transmission line has been included in the Muskrat Falls capital cost; while this was done to alleviate and reduce the supply risk should Muskrat Falls fail to commission on time, it is likely that that the line would be utilized to export power in the early stages when the power may not be required. The inclusion or non-inclusion may warrant a separate review if the cost is to be borne by NL customers.
- The optimization of the Muskrat Falls project has not been reviewed since 1998, in light of new project configurations and energy valuations a revision may be warranted (both in terms of installed capacity and height of infrastructure and assuming no development of Gull Island).
- Delaying the development of the Muskrat Falls (MF) and Labrador-Island Link (LIL) was not considered in the Navigant summary report on Decision Gate 2.



**CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVES**

**HIGH LEVEL REVIEW REPORT
(REF. NO. VA103-365/2-1)**

TABLE OF CONTENTS

	PAGE
EXECUTIVE SUMMARY	i
TABLE OF CONTENTS	i
SECTION 1.0 - INTRODUCTION	1
1.1 BACKGROUND	1
1.2 ENTITIES INVOLVED	1
1.2.1 Nalcor Energy	1
1.2.2 Board of Commissioners of Public Utilities	1
1.2.3 Manitoba Hydro International Ltd.	1
1.2.4 Consumer Advocate	2
1.2.5 Knight Piésold Ltd.	2
1.2.6 Navigant	2
1.2.7 Independent Project Review Team	2
1.2.8 Churchill Falls Labrador Corporation	3
1.3 SCOPE AND OBJECTIVES	3
1.3.1 Cumulative Present Worth	3
1.3.2 High Level Review	4
1.3.3 Limitations	4
1.3.4 Not Considered	4
1.3.5 Two Generation Expansion Alternatives	4
1.4 REFERENCE DOCUMENTS	5
SECTION 2.0 - DOCUMENT REVIEWS AND SUMMARY	6
2.1 COMPREHENSIVENESS	6
2.2 DOCUMENT REVIEW	6
2.3 CRITERIA SELECTION	6
2.3.1 Energy Criteria	6
2.3.2 Capacity Criteria	7
2.4 PROJECT COMPONENT DESCRIPTIONS	7
2.4.1 Muskrat Falls Hydroelectric Project (Variant 10)	7
2.4.2 Muskrat Falls to Churchill Fall Transmission Line	8
2.4.3 Labrador Island Link	8
2.4.4 Wind Power Facilities	8
2.4.5 Island Pond Hydroelectric Facility	9
2.4.6 Portland Creek Hydroelectric Facility	9
2.4.7 Round Pond Hydroelectric Facility	9



2.4.8	Combined Cycle Combustion Turbine Facility	10
2.4.9	Combustion Turbines	10
2.4.10	Holyrood Upgrades.....	10
SECTION 3.0 - LOAD AND GENERATION FORECAST REVIEWS		11
3.1	LOAD FORECASTS REVIEW.....	11
3.1.1	Load Forecast.....	11
3.1.2	Provincial Energy Plan	11
3.1.3	Load Shape	11
3.2	DEMAND SIDE MANAGEMENT.....	11
3.3	GENERATION FORECASTS.....	12
3.4	CAPACITY FACTOR ESTIMATES REVIEW	12
SECTION 4.0 - OPTIMIZATION REVIEW		13
4.1	OPTIMIZATION OF THE INTERCONNECTED ISLAND OPTION (ALTERNATIVE 1).....	13
4.1.1	Hydrology of Muskrat Falls	13
4.1.2	Increased Head at Muskrat Falls.....	13
4.1.3	Optimization of Muskrat Falls Installed Capacity	13
4.1.4	Phased Development	14
4.1.5	Upper Churchill Improvements Opportunities	14
4.2	TRANSMISSION OPTIMIZATION.....	14
4.3	OPTIMIZATION OF THE ISOLATED ISLAND OPTIONS	14
4.3.1	Wind Power Integration	15
4.3.2	Hydropower Resources	15
4.3.3	Optimization in Light of Thermal Offsets	15
4.4	NATURAL GAS	15
SECTION 5.0 - COSTS, DEVELOPMENT SCHEDULES AND FINANCIAL ANALYSES		17
5.1	COST ESTIMATE REVIEWS	17
5.1.1	Muskrat Falls	17
5.1.2	Labrador Island Link	18
5.1.3	Small Hydro	19
5.1.4	Wind.....	19
5.1.5	CCCT.....	19
5.1.6	CT	19
5.2	UNIT COST OF ENERGY	20
5.2.1	Federal Load Guarantee	20
5.3	SIMPLIFIED CPW ANALYSIS.....	20
5.3.1	Sensitivity Analysis of CPW.....	21
5.4	SCHEDULE	22
5.4.1	Timing of Project Development	22
5.4.2	Individual Project Development Schedule.....	22
5.4.3	IPR Team Review.....	22
5.4.4	Environmental Assessment.....	22
SECTION 6.0 - CONCLUSION AND RECOMMENDATIONS.....		24



6.1	CONCLUSIONS	24
6.2	RECOMMENDATIONS	24
6.2.1	Criteria Definition	24
6.2.2	Less Information, but More Clarity in Project Definitions	24
6.2.3	Comprehensive documentation.....	25
6.2.4	Bearing the Cost of the MF and LIL Development (i.e. Alternative 1 – Interconnected Island Option)	25
SECTION 7.0 - CERTIFICATION		26

TABLES

Table 2.1 Rev 0	Document Review
Table 5.1 Rev 0	Generation Portfolio Summary
Table 5.2 Rev 0	Basic Financial Analysis – MF & LIL
Table 5.3 Rev 0	Basic Financial Analysis – 170 MW CCCT (90% CF)
Table 5.4 Rev 0	Basic Financial Analysis – 170 MW CCCT (60% CF)
Table 5.5 Rev 0	Basic Financial Analysis – 50 MW CT
Table 5.6 Rev 0	Basic Financial Analysis – 50 MW CT – Capacity Payment
Table 5.7 Rev 0	Basic Financial Analysis – 25 MW Wind
Table 5.8 Rev 0	Basic Financial Analysis – 36 MW Island Pond Hydro
Table 5.9 Rev 0	Basic Financial Analysis – 23 MW Portland Creek Hydro
Table 5.10 Rev 0	Basic Financial Analysis – 18 MW Round Pond Hydro
Table 5.11 Rev 0	Simplified CPW Analysis

FIGURES

Figure 3.1 Rev 0	Projected Demand and Corresponding Supply – Isolated Island Option
Figure 3.2 Rev 0	Projected Demand and Corresponding Supply – Interconnected Island Option
Figure 5.1 Rev 0	High Level Review – Energy Cost vs. Development Year
Figure 5.2 Rev 0	Cumulative Present Worth Sensitivity Analysis



**CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVES**

**HIGH LEVEL REVIEW REPORT
(REF. NO. VA103-365/2-1)**

SECTION 1.0 - INTRODUCTION

1.1 BACKGROUND

The Government of the Province of Newfoundland and Labrador is proposing to develop the Muskrat Falls (MF) and Labrador-Island Link (LIL) projects as the preferred long-term power supply for the island of Newfoundland. This report will provide a high-level review of the information used to arrive at this recommendation.

1.2 ENTITIES INVOLVED

1.2.1 Nalcor Energy

Nalcor Energy was created in 2007 to manage the energy resources of the provinces of Newfoundland and Labrador. Nalcor Energy is a provincial Crown corporation under the Government of Newfoundland and Labrador. There are five lines of business under Nalcor Energy which include: Newfoundland and Labrador Hydro, the Churchill Falls Generating Station, The Lower Churchill Project, Oil and Gas and the Bull Arm Fabrication Site.

Nalcor Energy has provided the documentation reviewed herein to describe the process used to arrive at the decision to develop the Muskrat Falls (MF) and Labrador-Island Link (LIL) projects.

1.2.2 Board of Commissioners of Public Utilities

The PUB is an independent, quasi-judicial regulatory body appointed by the Lieutenant Governor in Council, and operates primarily under the authority of the Public Utilities Act. The Board is responsible for the regulation of the electric utilities in the province to ensure that the rates charged are just and reasonable, and that the service provided is safe and reliable.

The Provincial Government of Labrador and Newfoundland has asked the Board of Commissioners of Public Utilities (PUB) to provide an additional review of the process used to determine that Muskrat Falls represents the least-cost option for the supply of power to Island Interconnected Customers compared to an Isolated Island development option.

1.2.3 Manitoba Hydro International Ltd.

Manitoba Hydro International Ltd. is a wholly-owned subsidiary of the Manitoba electric power utilities. Manitoba Hydro International Ltd. (MHI) has been engaged by the PUB to perform a review of the Nalcor analysis.



1.2.4 Consumer Advocate

The Consumer Advocate ensures the effective representation of domestic and general service electricity customers in response to applications from public utilities and is appointed by the Government of Newfoundland and Labrador. Consumer advocate Tom Johnson has been appointed to represent consumer interests during the PUB review.

The Consumer Advocate takes part in the public consultation process organized by the PUB.

1.2.5 Knight Piésold Ltd.

Knight Piésold Ltd. (KP) is an independent, international consulting company specialising in power supply developments. The company was incorporated federally in Canada in 1975, and has had no prior involvement in any energy studies in the Province of Newfoundland and Labrador and bring an independent review role to this assignment.

Knight Piésold has been involved in hydropower projects for over 80 years and has recent, relevant experience in design and construction of new hydropower generating capacity in Canada. Knight Piésold also has in-house capabilities in wind power, thermal power and transmission.

Knight Piésold Ltd. has been asked by the Consumer Advocate to provide an independent high-level review of the assessments by Nalcor and MHI.

1.2.6 Navigant

The Muskrat Falls with the Labrador-Island Link was chosen as the preferred alternative to meet future energy needs during Decision Gate 2 (DG2).

Navigant, a consulting services firm, was retained by Nalcor to perform and report on the DG2 estimates. To prepare their findings, Navigant built and managed financial screening tools that allowed for rapid turn-around in the review of different planning scenarios, assessed and implemented methodologies for comparing resource options of different lives and sizes, and calculating the revenue requirement impacts of each resource option considered. Subsequent to their review Navigant prepared the "Independent Supply Decision Review."

1.2.7 Independent Project Review Team

The Independent Project Review (IPR) Team consisted of a small team of experts in project management, engineering, construction & commissioning. They were asked to perform a high-level independent expert assessment to ensure that decision-makers understand the completeness and issues associated with the deliverables on which they will base their decisions. The review focused on the Muskrat Falls Generation and Labrador island Link.

1.2.8 Churchill Falls Labrador Corporation

The Churchill Falls facilities are owned and operated by the Churchill Falls (Labrador) Corporation, CFLCo. It is owned by two shareholders: the Newfoundland and Labrador Hydro Corporation (65.8%), and Hydro-Quebec. CFLCo has a 99-year lease on the Churchill River watershed with the government of Newfoundland and Labrador. It was signed in 1961 and is renewable for a further 99 years. Based on those rights, CFLCo developed the site, which now produces approximately 34,000 GWh annually.

Under a 1969 contract, CFLCo sells the bulk of that power, about 30,000 MWh, to Hydro-Quebec. The remainder is sold to the iron-ore mines in western Labrador and to Newfoundland and Labrador Hydro. Regarding sales to Hydro-Quebec, the 1969 contract sets the price at \$2.50 per MWh which yields about \$75 million annually. Both the amount of power that must be sold to Hydro-Quebec and the price are points of contention.

1.3 SCOPE AND OBJECTIVES

The Board of Commissioners of Public Utilities (PUB) has been asked to review and report to Government on whether the Muskrat Falls (MF) and Labrador-Island Link (LIL) projects represent the least-cost option for the supply of power to Island Interconnected Customers over the period of 2011-2067, as compared to the Isolated Island Option. Nalcor Energy has provided the Newfoundland and Labrador PUB a series of documents and references to summarise the process used in their evaluation.

This review is limited to the comparison of the Two Generations Options presented to the Board by Nalcor as follows:

- Interconnected Island Option (Alternative 1):
 - 824 MW Muskrat Falls Hydro (MF) plus 50 MW CT on Island (Generation).
 - 900 MW HVDC Labrador Island Link (LIL) (Transmission).
- Isolated Island Option (Alternative 2):
 - 25 MW Wind Power Purchase Agreement.
 - 36 MW Island Pond, 23 MW Portland Creek and 18 MW Round Pond Hydro Facilities.
 - Holyrood Upgrades.
 - 170 MW CCGT, and incremental 50 MW CT additions.
 - Holyrood Replacement post 2030 with additional Thermal Generation added as the load grows.

1.3.1 Cumulative Present Worth

The culmination of the presented generation planning analysis by Nalcor is the comparison of the Cumulative Present Worth (CPW). The CPW is the present value of all incremental utility capital and operating costs incurred to reliably meet a specific load forecast given a prescribed set of reliability criteria. Nalcor's documentation shows that the Interconnected Island Option has a lower CPW than the Isolated Island Option, and is thus Nalcor's recommended Option, consistent with the provision of mandated least cost electricity services.



1.3.2 High Level Review

For the purpose of this review, information was looked at broadly honing in on the aspects or components that were most likely to affect the overall outcome and decision. For example the exact capital cost of each of the potential island options does not have as much repercussions as the single cost of the LIL.

1.3.3 Limitations

Beyond expressing our opinion of the information provided, Knight Piésold did not have access to the detailed costing information and other "confidential" information to develop the same system wide risk based planning tools developed by Newfoundland and Labrador Hydro (Strategist model) and Navigant, and to be developed by Manitoba Hydro International. Thus our numerical analysis was simplified to incorporate a review of payments for average annual energy.

This high level review does not constitute an audit or validation of Nalcor's work. However, it will provide the Consumer Advocate with a document that highlights the high risk areas and components of the two generations options that have the greatest impacts on the CPW.

1.3.4 Not Considered

This report did NOT review:

- The environmental implications of the alternatives
- The retrieval of energy from Churchill Falls
- The use of renewable vs. non-renewable resources
- The legislated requirements, or
- The value and potential of electricity exports.

It is expected that any of the above aspects, if taken into account, could provide a different set of conclusions when the two generation expansion options are compared, as compared to limiting the selection criteria to the CPW Analysis.

1.3.5 Two Generation Expansion Alternatives

The major components and time-frames for the **Two Generation Expansion Alternatives** as put forward by Nalcor are as follows:

Alternative 1: (the "Projects")

- Installation of a 50 MW combustion turbine in 2014.
- Development of the 824 MW hydroelectric potential at Muskrat Falls on the Lower Churchill River in Labrador and completion of a nominal 900 MW HVDC link, including submarine cables across the Strait of Belle Isle, to the Island of Newfoundland in 2016. Coincident with this, the nominal 500 MW oil-fired Holyrood Thermal Generating Station (HTGS) on the Island would be placed on standby.
- Retirement of the HTGS in 2021.



- Installation of primarily thermal capacity in the 2030 to 2067 timeframe.

Alternative 2: (Isolated Island Option):

- Installation of a 25 MW wind farm in 2014.
- Completion of the 36 MW Island Pond hydroelectric plant on the Island in 2015.
- Upgrades to the HTGS including the addition of electrostatic precipitators, scrubbers and NOX burners in the 2015 to 2017 timeframe.
- Completion of the 23 MW Portland Creek hydroelectric plant on the Island in 2018.
- Completion of the 18 MW Round Pond hydroelectric plant on the Island in 2020.
- Installation of a 170 MW combined cycle combustion turbine in 2022.
- Installation of 50 MW combustion turbines in 2024 and 2027.
- Installation of 50 MW of wind capacity in 2029.
- Replacement of the HTGS and the addition of more thermal capacity in the 2030 to 2067 timeframe.

1.4 REFERENCE DOCUMENTS

Documents provided by Nalcor energy to the Newfoundland and Labrador Board of Commissioners of Public Utilities:

- Synopsis of 2010 Generation Expansion Decision, Nalcor Energy, July 2011.
- Exhibits 1 through 101.
- RFI Responses Batch 01 through Batch 32; including MHI-Nalcor, PUB-Nalcor, and Response to Board Question 3-4.
- Muskrat Falls Development, Presentation to the PUB, July 2011.

Supplemental Documentation:

- Report of the Joint Review Panel established by Canada's Minister of the Environment, the Minister of Environment and Conservation for Newfoundland and Labrador, and the Minister for Intergovernmental Affairs for Newfoundland and Labrador, Lower Churchill Hydroelectric Generation Project, Nalcor Energy, Newfoundland and Labrador, August 2011. CEAA Reference No. 07-05-26178. Department of Environment and Conservation Registration No.: 1305.
- Focusing Our Energy, Newfoundland and Labrador Energy Plan, September 2007.
- Independent Supply Decision Review prepared for Nalcor Energy by Navigant Consulting Ltd, September 14, 2011.
- LNG related Documents:
 - Order Granting Long-Term Multi-contract Authorization to Export LNG by Vessel from the Cove Point LNG Terminal.
 - Dominion Cove Point LNG, Application for Long-Term Authorization to Export LNG to the USA Department of Energy.
 - Response to Newfoundland and Labrador Energy Plan Discussion Paper by the Canadian Association of Petroleum Producers.



SECTION 2.0 - DOCUMENT REVIEWS AND SUMMARY

The purpose of this section is the identification of any gaps in the data provided by existing reports and recent studies that could have a bearing on the analysis and recommendations.

2.1 COMPREHENSIVENESS

Given the limited time available for the review of the information and sheer volume of information it is unfortunate that it was not presented in a more comprehensive fashion. The number of subsequent key questions by MHI and PUB reflects that the documentation was, generally speaking, not packaged in an effective manner or with the most relevant material presented clearly upfront. The recently released "Independent Supply Decision Review" prepared by Navigant Consulting was instrumental in understanding the process used to arrive at the proposed recommendation and the sensitivity of the recommendation to a number of factors.

The IPR Team noted that the processes and methods used for Risk Analysis, Estimating and Economic analysis complied with appropriate standards and best practices and they observed a good association between the Economics, Estimating and Finance teams. While Knight Piésold trusts the methodologies and rigor of the work undertaken, summarized findings with the clear reference to the supporting material was not often present.

2.2 DOCUMENT REVIEW

Table 2.1 presents a list of all the documents made available to Knight Piésold as of: October 7, 2011. A one line comment about the various documents has also been included in Table 2.1.

2.3 CRITERIA SELECTION

Two aspects of the planning criteria have been generally accepted, but no particular sensitivity analysis was presented surrounding these criteria, which themselves have a bearing on the overall supply selection. The criteria are: Capacity and Energy.

Section 3 of the Nalcor's Synopsis defines the terms:

- "Energy: The Island Interconnected System should have sufficient generating capability to supply all of its firm energy requirements with firm system capability."
- "Capacity: The Island Interconnected System should have sufficient generating capacity to satisfy a Loss of Load Hours (LOLH) expectation target of not more than 2.8 hours per year."

2.3.1 Energy Criteria

Despite the term "firm demand" and "firm capability" having varying definitions from jurisdiction to jurisdiction the energy criteria is a sensible criterion from an energy quantity perspective. If this criterion forms the basis for the decision making then the terms should be clearly defined; i.e. firm annual supply, firm seasonal supply, etc.

While the reliability of the system should be evaluated, the economic basis could be evaluated on an average basis or some other statistical basis. However, from a cost analysis perspective the sole use of firm supply would tend to be a conservative estimate of the renewable energy supplied and therefore increase the average amount of thermal supplement required, it appears from Exhibit 100 that the average was used.

2.3.2 Capacity Criteria

The capacity criteria have an implication affecting the preferred supply option. Generally speaking, if the customers of N&L were willing to accept a less reliable electrical supply source or on the contrary required a more reliable network, then this criterion would change. We can only assume that this criterion was derived as an optimal target, but it is was not possible to ascertain if it was biased towards the Interconnected Island Option (Alternative 1) in the first place.

This high level review has not reviewed whether or not the proposed alternatives achieve the given LOLH Criteria.

2.4 PROJECT COMPONENT DESCRIPTIONS

Our understandings of the proposed developments are as follows:

2.4.1 Muskrat Falls Hydroelectric Project (Variant 10)

Muskrat Falls Design Basis is shown in Muskrat Falls Project - Exhibit 30 Page 13 of 24. The Muskrat Falls facility would consist of two dams, a reservoir and a generation facility having a total capacity of 824 MW. The two dams would be constructed of roller compacted concrete. The north dam with crest at 39.5 masl and 430 metres in length, and the south dam with crest at 45.5 masl and 325 m in length. The powerhouse would be an above-ground structure that would house four Kaplan turbines, each with a capacity of 206 MW giving a total installed capacity of 824 MW. The project indicative gross head is 35.5 m (39 masl – 3.5 masl). Water for each turbine would be delivered to the generating units via 9-metre diameter penstocks. The total discharge from the powerhouse would be 2,660 m³/s. The spillway would accommodate a probable maximum flood of 22,420 m³/s. The long term average flow at Muskrat Falls is 1,841 m³/s (2,026 m³/s with the Romaine and St-Jean diversions). The facility will be capable of generating 4,900 GWh annually, according to Appendix B, p 37.

Parameter	DG2 Design
Layout	Variant 10, Scheme 3b
Power Generation Capacity	824 MW
Annual Energy Production	4,900 GWh
Turbines	4 x 216 MW Kaplan
Main Dam	RCC
Temporary Diversion Scheme	Spillway
Spillway	4 radial gates
Access	South Side Access Road

Camp	1,500 people
------	--------------

Based on the documentation reviewed in this report it appears that:

- The Muskrat Falls Hydroelectric Development is technically feasible.
- Continued studies are underway to reduce risks and contingencies in the cost estimates.
- Previous and recent geotechnical investigations indicate foundations are suitable for the given structures.
- Proposed structures and electrical and mechanical equipment are conventional.
- The North spur stabilization layout is technically feasible.
- The project construction schedule is aggressive.

2.4.2 Muskrat Falls to Churchill Fall Transmission Line

The capital cost estimate for Muskrat Falls to Churchill Falls transmission line was lumped in with the Muskrat Falls Project cost, a description is provided p. 5 of Exhibit 59: "For project costing it is recommended that two 345 kV transmission lines with a two conductor bundle of 795 MCM 26/7 ACSR "DRAKE" per phase be assumed. In addition, to ensure acceptable voltage control on line open end conditions, four 345 kV, 45 MVAR shunt reactors (one per each transmission line end) be included." This line is principally presented as a reliability component.

Parameter	DG2 Design
Operating Voltage	2 x 345 kV
Overall Transmission Length	245 km

2.4.3 Labrador Island Link

The Labrador Island Link consists of a 320 kV high voltage direct current (HVdc) transmission line, approximately 1,100 km long.

Parameter	DG2 Design
Operating Voltage	320 kV
System Capacity	900 MW
Number of Submarine Cables	3 off
Overall Transmission Length	1,050 km
Submarine Cable Route	35 km

Analysis carried out in June and July of 2010 confirmed that a 900 MW HVdc link between Labrador and the Island would require a minimum operating voltage of ± 320 kV to ensure that transmission losses for the proposed HVdc system would be in the order of 10% over peak periods.

2.4.4 Wind Power Facilities

Newfoundland has an abundant wind resource with a significant potential for wind-power development. There are operational constraints that limit the amount of additional

non-dispatchable generation that can be added to the system. A nominal 25 MW wind farm is reportedly expected to generate a reported estimated annual firm and a reported average energy capability of approximately 70 and 110 GWh, respectively; yielding respective capacity factor equivalents of 32% and 50%. The given capacity factors appear high and will need to be confirmed with the long term data from the existing wind farms of Fermeuse and St. Lawrence.

2.4.5 Island Pond Hydroelectric Facility

Island Pond is a proposed 36 MW hydroelectric facility located on the North Salmon River, within the watershed of the existing Bay d'Espoir development. The project would use roughly 25 m of net head between the existing Meelpaeg Reservoir and Crooked Lake to produce an annual firm and average energy capability of 172 GWh and 186 GWh, respectively; yielding respective capacity factor equivalents of 54% and 59%.

The development would include a 3 km diversion canal between Meelpaeg Reservoir and Island Pond, which would raise the water level in Island Pond to that of the Meelpaeg Reservoir. Also, approximately 3.4 km of channel improvements would be constructed in the area. At the south end of Island Pond, a 750 m long forebay would pass water to the 23 m high earth dam, and then onto the intake and powerhouse housing a single Kaplan turbine generator with a full load flow of 182 m³/s, and finally discharging it into Crooked Lake via a 550 m long tailrace.

The facility would be connected to TL263, a nearby 230 kV transmission line connecting the Granite Canal Generating Station with the Upper Salmon Generating Station.

2.4.6 Portland Creek Hydroelectric Facility

Portland Creek is a proposed 23 MW hydroelectric facility located on Main Port Brook, near Daniel's Harbour, on the Northern Peninsula. The project would utilize 395 m of net head between the head pond and outlet of Main Port Brook to produce an annual firm and average energy capability of 99 GWh and 142 GWh, respectively; yielding respective capacity factor equivalents of 49% and 70%.

The project would require: a 320 m long diversion canal; three concrete dams; a 2,900 m long penstock and a powerhouse housing two Pelton turbine generators, a 27 km 66 kV transmission line from the project site to Peter's Barren Terminal Station; and the construction of access roads.

2.4.7 Round Pond Hydroelectric Facility

Round Pond is a proposed 18 MW hydroelectric facility located within the watershed of the existing Bay d'Espoir development. The facility would utilize the available head between the existing Godaleich Pond and Long Pond Reservoir (approximately 11 m) to produce an annual firm and average energy capability of 109 GWh and 132 GWh, respectively; yielding respective capacity factor equivalents of 69% and 83%. Flows are regulated by the Upper Salmon Generating Station, in addition to the natural drainage from Round Pond basin itself.



The plant design flow is around 193 m³/s. (A design factor of 1.2 considering a Mean Annual Discharge of 163 m³/s.) The facility includes large pieces of infrastructure: a 800 m earth fill dam, a 1,050 m saddle dam, a spillway dam, a 290 m power canal, an 80 m fish passage facility.

2.4.8 Combined Cycle Combustion Turbine Facility

The combined cycle facility, also known as a combined-cycle combustion turbine (CCCT) facility, consists of a combustion turbine fired on light oil (in the absence of natural gas), a heat recovery steam generator, and a steam turbine generator.

Two sites have been considered by Nalcor: one alternative for a proposed combined cycle plant located at the existing HTGS to take advantage of the operational and capital cost savings associated with the existing facilities. The other alternative is to develop a greenfield site at a location yet to be determined. The greenfield alternative may be preferred due to environmental constraints that may be placed on any new developments at Holyrood and reduce the risk of loss of multiple generation sources in the event of major events.

The power ratings being considered herein were for a 170 MW CCCT facility, capable of generating approximately 1,340 GWh annually.

2.4.9 Combustion Turbines

Combustion turbines (CTs) are designed to start quickly to meet the demand for electricity during peak operating periods. The proposed CTs are fired on light oil. These simple-cycle combustion turbines nominally rated at 50 MW (net), would be located either adjacent to similar existing units at Hydro's Hardwoods and Stephenville Terminal Stations, at the Holyrood site or at greenfield locations. If required, they can be utilized to provide an annual firm energy capability of 394 GWh each (a 90% Capacity Factor).

2.4.10 Holyrood Upgrades

Newfoundland and Labrador Hydro (Hydra) operates a 500-MW heavy oil fired generating plant at Holyrood on Conception Bay. The plant consists of three units. Units 1 and 2 were commissioned as 150 MW units in 1969, and Unit 3 was commissioned as a 150 MW unit in 1980. In the late 1980s, Units 1 and 2 were uprated to 175 MW each, bringing the total capacity to 500 MW. No air emissions control equipment exists on any of the units. Upgrades are required for continued use of the facility.



SECTION 3.0 - LOAD AND GENERATION FORECAST REVIEWS

3.1 LOAD FORECASTS REVIEW

3.1.1 Load Forecast

The load forecasts (from 2010) were provided in Exhibit 1, the numbers provided are developed by the Market Analysis Section, System Planning Department of Newfoundland and Labrador Hydro.

The numbers supplied have been well accepted during the planning phase and the methods employed are consistent with standard utility practice, therefore are accepted as presented. Navigant has noted that the projected growth is comparable (slightly less than) to the electrical energy growth rates in Canada overall.

3.1.2 Provincial Energy Plan

The Provincial Energy Plan outlines the long-term vision for developing Newfoundland and Labrador. The relevant Energy Plan objectives are meeting the provincial electricity needs, re-investing wealth from non-renewable oil resources into renewable projects, and replacing Holyrood Thermal generating Station (HTGS) with non-emitting alternative, or installing scrubbers and electrostatic precipitators.

The Energy Plan confirms broadly the projected continued increase in demand and capacity requirement reflected in these numbers through 2067. The switch to electric heat is cited as the primary driver of the increase in electricity demand. Additional accepted assumptions in the forecast include:

- Continued operations of the Island newsprint mill and oil refinery
- Continued operations of the Teck mine through 2013
- Full production of the Vale Nickel processing facility by 2015, and
- Continued growth led by the development of the Hebron oil field.

3.1.3 Load Shape

The load shape shared in Exhibit 2, indicates that the hourly peak demand rises to 30% over average annual energy requirement. In the load forecast the peak energy requirement is roughly 72-75% over the average energy requirement.

3.2 DEMAND SIDE MANAGEMENT

Whether it is expected to count as a supply or a reduced load, no quantification of demand side management (DSM) was provided. Exhibit 16 – Generation Planning Issues mentions a number of energy conservation programs and states their success, yet no metric of the impact is indicated. It further states:

"The impact of energy conservation measures resulting from the Five-Year Energy Conservation Plan will need to be evaluated to determine what, if any impact, it has on the decision for the next



source. At this time, it is expected that the principal benefits will be the economic and environmental benefits of the reduced reliance on HTGS produced electricity and that the timing for the next decision will be unaffected."

Navigants "Assumptions for Island Demand and Supply" indicate that a realistic level of DSM could yield an annual savings of 750 GWh at the end of a 20 year period of aggressive DSM programs, regulations, codes and standards. "Realizing this level of saving would require investing approximately \$400 million in energy efficiency over 20 years." Even at these costs the returns far exceed what can be achieved by traditional supply means. It is therefore recommended that DSM be presented as a viable supply that could meet a measurable portion of the forecasted demand growth.

Furthermore, if aggressive demand side management is pursued independently then the forecasted energy demand from the Muskrat Falls (MF) generation facility may be impacted, and since the MF project is amortized over the projected energy consumption, there may be a resulting impact on the cost per unit energy of MF.

3.3 GENERATION FORECASTS

Figures 3.1 and 3.2 illustrate the forecasted demand and average means of meeting that demand as provided by Nalcor in Exhibit 100 (released October 4, 2011) in both the Interconnected Island Scenario and the Isolated Island Scenario. Visually one can observe the small role played by average non Labrador Island Link supplies in the Interconnected Option, and the relatively small proportion of the renewable component in the Isolated Island Scenario.

The general makeup of the supply is reasonable with renewable sources taking precedent over thermal sources.

3.4 CAPACITY FACTOR ESTIMATES REVIEW

Firm capability for the hydroelectric resources is the firm energy capability of those resources under the most adverse three-year sequence of reservoir inflows occurring within the historical record. Firm capability for the thermal resources (HTGS) is based on energy capability adjusted for maintenance and forced outages.

The overall rates are reasonable in each case, with exception of the high wind capacity factor, but it is not significant overall.



SECTION 4.0 - OPTIMIZATION REVIEW

It is debatable as to whether the two options as presented by Nalcor were indeed the optimal options to compare. Particularly in the Isolated Island scenario, while the Navigant report did breach some of the information gaps, the full spectrum of isolated island options was not shared.

4.1 OPTIMIZATION OF THE INTERCONNECTED ISLAND OPTION (ALTERNATIVE 1)

The Muskrat Falls project has been repeatedly shown as a fixed 824 MW facility, but there may be options surrounding the development. Any improvement in the optimization of Muskrat Fall should only help lean the selection towards the interconnected option.

4.1.1 Hydrology of Muskrat Falls

A flow duration curve for Muskrat Falls is presented in the 1999 Feasibility Study (pdf p. 545, 1999 Feasibility Study.) It shows an exceedance probability over 80% for a flow of 1,600 m³/s and 15% for a flow of 2,400 m³/s. With roughly 35m of net head this bracket corresponds very roughly to 500 - 750 MW of installed capacity. Given the indicated exceedance probability curve a 500 MW plant would have a very firm energy profile capable of generating over 4,000 GWh annually. Note: it is unclear whether this curve includes the Romaine and St-Jean diversions. Section 5.3 of the 1999 Feasibility Study indicates that the potential size of the Muskrat Falls project could vary from 618 MW to 1,236 MW.

With a reported 824 MW installed capacity, 2,660 m³/s design flow, 4,900 GWh of annual generation, there is some capacity valuation to the final recommended installed capacity over an energy valuation or logical development economies associated with sunk development costs.

4.1.2 Increased Head at Muskrat Falls

Increasing the impoundment elevation at Muskrat Falls would limit any future development of Gull Island, but allow for more energy to be produced at Muskrat Falls. In RFI Response MHI-Nalcor 74, Nalcor states that it does not intend to develop Muskrat Falls in isolation of Gull Island. A configuration of Muskrat Falls may therefore exist that is more optimal to the consumer if the consumer is to bear the development cost.

4.1.3 Optimization of Muskrat Falls Installed Capacity

According to Section 5.3 of the 1999 Feasibility Study the project was optimized on the basis of capital costs for varying sizes and economic factors assumed for evaluating energy and capacity benefits, as supplied by Newfoundland and Labrador Hydro were:

- "Present value of 1 TWh per year for fifty year project life and 10% interest rate = \$225,000,000"
- "Value of 1 MW capacity = \$550,000"

While the metric for the recommended installed capacity has most likely changed since the 1998 studies, the optimization of the projects installed capacity has not been revised since. Assuming



a unit rate of 75 \$/MWh, at 2% escalation, for 50 years at 10% interest puts the NPV in excess of \$1 billion.

The report further refers to "Acres International Ltd., (1998), Churchill River Complex - Optimization Study, (In progress), P12859.00." not provided or reviewed herein.

According to the IPR Team Muskrat Falls has been optimized within the overall development plan of the river, it did not indicate whether Muskrat Falls was optimized in the context of providing power to Newfoundland. The end difference could be that the Newfoundland consumers would be paying for a larger or smaller piece of infrastructure than specifically necessary to meet their demand in an optimal way.

4.1.4 Phased Development

The proposed Muskrat Falls Development has not been optioned as a phased development where all turbine generators are not installed on the onset. There are undoubtedly large economies in terms of installation costs and mobilization for installing all equipment during the initial development however the turbine generators are also large ticket items and differing the installation of one or two of the turbines could differ the expenditures in excess of \$100 to \$200 million in initial capital.

4.1.5 Upper Churchill Improvements Opportunities

The system model schematic (pdf p.93 – 1999 Muskrat Falls Feasibility Study) shows the complexity of the Upper Churchill Falls system upstream of Muskrat Falls. There may be a number of system upgrades or capital improvement projects that could be expanded to provide generation beyond the current capability. While it is understood that this consideration was not covered under the current mandate, the question is posed since the current Muskrat Falls and LIL option already extend from Muskrat Falls to the Upper Churchill system.

4.2 TRANSMISSION OPTIMIZATION

The available transmission options have been studied (e.g., transmission to the island, transmission through Quebec to US, transmission thru Newfoundland to the Maritimes). The only option that warrants consideration for supply power to Newfoundland is the Labrador Island Link (LIL) and the alignment, voltage and channel crossing designs have been further optimized by Nalcor over the last decade. There appears to be room for further optimization of the Muskrat Falls to Churchill Falls transmission line, and there is obviously a benefit to exporting any excess energy from the system, but this has not been evaluated as part of this study.

4.3 OPTIMIZATION OF THE ISOLATED ISLAND OPTIONS

While reviewing the information provided by Nalcor, the question of whether the Isolated Island Option put forth was indeed the optimal and least cost option for an Isolated Island development was nagging. The recently released Navigant Report outlines the parameters leading to the proposed option and reinforces the options recommended by Nalcor.



It was noted that the mandate of the Independent Project review, performed by a team of four independent experts was to focus on the Muskrat Falls Generation and Island Link and not the Isolated Island Options; as such the Isolated Island Option may not have undergone the same level of scrutiny.

While Knight Piésold concurs with the dismissal of Solar and Nuclear sources on the basis stated by Navigant, there are still outstanding questions with regards to the on Island hydropower and gas (LNG) generation opportunities.

4.3.1 Wind Power Integration

Navigant's assessment and Exhibit 61's both indicate that a larger amount of Wind Power can be integrated in the generation mix, particularly in instances where supplemental capacity has been added to the system. As wind power is competitive versus the thermal alternatives it is expected that the presented option may be slightly sub-optimal (i.e. additional wind power integrations could be considered).

4.3.2 Hydropower Resources

It may be worth revisiting the 1986 Study performed by Shawmont Newfoundland that identified 196 potential hydro sites to ensure there are no hidden assets. Furthermore, it has been Knight Piésold's experience that older hydroelectric studies typically limited themselves to a traditional vision of firm hydropower as opposed to a renewable vision of intermittent run-of-river hydropower with larger energy generation capabilities. KP has not had access to this 1986 study to review.

Navigant indicated that seven proposals were received for selection in response to a 1992/93 hydroelectric procurement process with average bid prices of 102\$/MWh (in today's prices, as updated by Navigant). This immediately raises the query as to why only three on island hydroelectric projects are considered in Alternative 2 (i.e. Isolated Island Option)?

4.3.3 Optimization in Light of Thermal Offsets

The indicated capacity factors for the 3 proposed hydroelectric facilities are generally high indicating that they are either on highly regulated systems (Round Pond, Island Pond) or optimized with a firmer yield in mind. If the individual facilities are designed on the basis of their individual cost benefit ratios there is could be an opportunity to significantly increase their energy generation potential and thereby offset expensive thermal generation. Simply put, it is likely that the proposed hydroelectric facilities could have larger installed capacities than those indicated, though the amount is probably not significant when compared to the total increase in demand to 2067, but still worth consideration.

4.4 NATURAL GAS

Newfoundland and Labrador has witnessed strong growth in its oil and gas sector and Nalcor has an active role in the exploration and development of oil and gas resources both offshore and onshore. Natural gas is produced in Newfoundland and Labradors offshore areas and could be transported to



Newfoundland, either as gas in a pipeline or in a Liquefied Natural Gas (LNG) tanker. Once onshore, gas could be used to generate electricity through CTs, a significantly more efficient method than fuel oil and producing far less GHGs and other emissions. While there is significant gas resource offshore of Newfoundland, a majority of the resource occurs as solution gas in an oil pool or as a "gas cap." The development and availability of this resource will depend on oil development and will generally occur only after an oil resource has been depleted.

As a result, a provincial plan for gas development may be feasible. Hibernia, Terra Nova, and White Rose have the potential to contribute reserves. Within a decade these oilfields may have surplus gas available for export. As stated explicitly in the Newfoundland and Labrador Energy Plan: "The economic feasibility of gas-to-wire will depend on a variety of factors, such as the total cost of producing, delivering and converting gas to electricity, compared to the current market value of electricity in the targeted marketplace."

A series of articles forwarded to Knight Piésold by the Consumer Advocate point out that Dominion Cove Point LNG is poised to export LNG out of the US. Projected costs for LNG are low and bearing the appropriate infrastructure could be very cost competitive. If LNG was available at projected competitive market rates then gas fired generation could most likely be developed at a cost much less than Muskrat Falls, especially in the short term.

The economic feasibility of gas-to-wire will depend on the total cost of producing, delivering and converting gas to electricity, as compared to the current market value of electricity in the Newfoundland. Conditions necessary for gas to wire development are:

- Gas Resources must be accessible either through the ability to import LNG or through offshore development and supporting infrastructure (a pipeline)
- Available Gas Handling Capacity
- Compatibility with Oil Developments, and
- Compelling Economics.

There are a number of long term policy items here that go far beyond the scope of this review: what resource does the province wish to pursue, does pursuing Muskrat Falls hinder the development of gas resources, what are the resource sector risks, what is the cost of the loss of gas sales, etc. Nalcor and Navigant both indicated correctly that there was no immediate firm development plan to bring natural gas to the Island, and assumed it was sufficient for their consideration.



SECTION 5.0 - COSTS, DEVELOPMENT SCHEDULES AND FINANCIAL ANALYSES

5.1 COST ESTIMATE REVIEWS

Knight Piésold has reviewed the overall costs of MF and LIL with extremely limited access to layouts, bill of quantities or breakdowns of the project costs. A very cursory review of the isolated island option was also undertaken. Table 5.1 contains a summary of the projects cost shared by Nalcor and Navigant.

5.1.1 Muskrat Falls

Very broadly speaking, investment costs of large hydropower plants range from \$2 million/MW to \$10 million/MW. It is very site-sensitive, with a typical figure of about \$4 million/MW. Operation and maintenance (O&M) costs of hydropower are between 1.5% and 2.5% of investment cost per year. The Muskrat Falls Facility fits within this bracket at around \$3 million/MW without the LIL, and \$6 million/MW with the LIL.

The cost estimate for Muskrat Falls is in the right order of magnitude and generally appears adequate without access to the details. Two components appear conservative: the intake and powerhouse component and the development costs. A review of a Bill of Quantities could help ascertain their appropriateness. The Muskrat Falls to Churchill Falls Transmission Line based on lineal unit costs over the two x 245 km lines appears largely underestimated.

Item	Nalcor	KP Order of Magnitude Review	Impression of Cost Estimate
Site	373 M\$	290 M\$	Adequate
<ul style="list-style-type: none"> Site Preparation Access 		Guess = 50 M\$ 375 km of new or upgrades at 100\$/m = 37 M\$	Depends largely on clearing access.
<ul style="list-style-type: none"> Site Services, Accommodations Complex and Catering Reservoir Clearing 		1,500 pers x 30,000\$ pers/yr x 4 years = 180 M\$ 390,000 m ³ of timber at 50\$/m ³ = 20 M\$	Recovery Value?
Power	923 M\$	660 M\$	Adequate
<ul style="list-style-type: none"> Intake 		0.2 M\$/MW x 824MW = 165 M\$	TBD, No General Arrangements
<ul style="list-style-type: none"> Powerhouse 		0.2 M\$/MW x 824MW = 165 M\$	TBD, No General Arrangements
<ul style="list-style-type: none"> Turbine Generator 		0.4 M\$/MW x 824MW = 330 M\$	Adequate
Dams	274 M\$	275 M\$	Adequate
<ul style="list-style-type: none"> Spillway Structure RCC Dams 		Guess = 50 M\$ 2.5 M m ³ x 50\$/m ³ = 125 M\$	

Knight Piésold CONSULTING

• Cofferdams		Guess = 50 M\$	
• North Spur Stabilization		Guess = 50 M\$	
Interconnection	261 M\$	400 M\$	Low!
• Switchyards		30 M\$	
• MF to CF Transmission Lines		2 x 245 km 345 kV x 0.75 M\$/km = 370 M\$	
Development Costs	375 M\$	14% of 1,831 M\$ = 256 M\$	High
• Feasibility Studies		1%	
• EA		1%	
• Insurance		2%	
• Engineering and Design		8%	
• Project Management		2%	
Escalation Allowance	335 M\$		Adequate
Estimate Contingency	328 M\$		Adequate 15% of Cost
Total	2,869 M\$		Reasonable

The IPR team noted that while there was no defined estimating process for NALCOR mega-projects, but that the Gate 2 estimate was planned and carried out in accordance with a project-specific process. The IPR team noted that the change to "MF first" placed time pressures on the estimating process documentation, but that the methodology used was consistent with best practice for this type of project at Gate 2. It is KPs view that this "documentation", is vital in the proper review of the costs of the Muskrats Falls development, and reiterate the IPR teams comment that considerable work to complete the Gate 2 estimating package needs to be completed.

5.1.2 Labrador Island Link

HVDC has been used in transmission since 1954, and is presented by vendors (ABB) as a competitive economic choice for distances over 800 km. Again the cost per km of the HVdc Overland Transmission appears low.

Item	Nalcor	KP Order of Magnitude Review	Impression of Cost Estimate
• Converter Stations, Electrodes, and Switchyards	466 M\$		Adequate
• SOBI Cable Crossing Land Sites, and Transition Compounds	324 M\$	35 km x 10 M\$/km = 350 M\$	Adequate
• HVdc Overland Transmission	400 M\$	1,050 km x 0.75 M\$/km = 790 M\$	Low!

Knight Piésold
 CONSULTING

• Island System Upgrades	194 M\$		
• Development Costs	232 M\$	16% of 1,384 M\$ = 221 M\$	Adequate
• Escalation Allowance	208 M\$		Adequate
• Estimate Contingency	236 M\$		Adequate 15% of Cost
Total	2,060 M\$		A little Low

5.1.3 Small Hydro

As expressed in RFI #4, "given the findings by Nalcor... the Interconnected Scenario holds a \$2.2 billion dollar CPW advantage over the Isolated Scenario, and is therefore the preferred solution; no action has been taken to update the cost estimates for these projects, except to escalate them annually. Nalcor does not believe that further study beyond that undertaken would reduce the costs of these projects. To the extent that any increase in costs would only increase the preference of the Interconnected Scenario, further efforts to update these cost estimates are not warranted."

It is Knight Piésold's opinion that the following key aspects of the project should and could easily be updated to ensure an apples to apples comparison of the two options:

- Installed Capacities and Energy Generation Potential.
- Capital and Operating Cost Estimates.

5.1.4 Wind

Costs presented were generally conservative, but acceptable.

5.1.5 CCCT

The capital cost estimate for the Holyrood Combined Cycle Plant is based on the Combined Cycle Plant Study Update, Supplementary Report which was completed in 2001, with a review by Hydro's Mechanical Engineering Department in 2009 and updated to 2010.

5.1.6 CT

The capital cost estimate for these units was reviewed in 2009, by Hydro's Mechanical Engineering Department and updated in 2010. Approximately 90 percent of the direct cost is for the gas turbine package and due to recent fluctuations in demand for gas turbines; prices remain volatile. Hydro should continue to monitor turbine prices to determine when a further in-depth review of the capital cost estimates becomes necessary.



5.2 UNIT COST OF ENERGY

Using the material provided by Nalcor and Navigant, Knight Piésold calculated the expected development cost for the various supply sources are as follows:

Unit Cost of Energy (2010 \$/MWh) escalated at 2%

	6% IRR	8% IRR	10% IRR	15% IRR
• Muskrat Falls and LIL (Sale as Needed)	88	131	183	357
• Muskrat Falls and LIL (Full Sale)		79	104	181
• 170 MW CCCT (90% C.F.)		228	231	239
• 170 MW CCCT (60% C.F.)		239	243	255
• 50 MW CT (90% C.F.)		273	276	283
• 25 MW Wind		70	80	110
• 36 MW Island Pond		68	85	138
• 23 MW Portland		47	58	90
• 18 MW Round Pond		79	99	160
• Average 75 MW Wind – 77 MW Hydro		67	81	123
• Conservation		32	40	60

Tables 5.2 through 5.10 present the assumptions and calculations for the various power supply options. Figure 5.1, shows that the time of development has very little influence on the bearing of the 2010 unit cost of energy escalated at 2%. In the case of thermal supplies, development is slightly cheaper in the earlier decades. The results are summarized in Table 5.1 as well.

It is interesting to note that on a mix basis to achieve the unit cost of energy of Muskrat Falls and the Labrador Island Link requires an Isolated Island option that includes an energy supply with about 70% from renewables, which is not available in the current options.

5.2.1 Federal Load Guarantee

In August 2011, Canada's federal government pledged to cover the \$6.2 billion cost of the first phase of the Lower Churchill Project, the construction of the Muskrat Falls plant, with Federal Loan guarantees, which will lower borrowing costs by 2%.

5.3 SIMPLIFIED CPW ANALYSIS

A simplified CPW analysis was conducted using the projected energy balance and unit rates for energy (escalated at 2% annually) of:

- 131 \$/MWh for Muskrat Falls and the Labrador Island Link
- 81 \$/MWh for renewable energy (Hydro or Wind), and
- 243 \$/MWh for thermal energy (corresponding to a CCCT at 60% capacity factor).



The results are presented in Table 5.11:

- A CPW of the Interconnected Island Scenario of: \$6.8 billion CAD.
- A CPW of the Isolated Island Scenario of: \$9.5 billion CAD.
- A difference of: \$2.7 billion CAD in favour of the Interconnected Island Option.

The Nalcor studies showed CPWs of \$6.7 and \$8.8 billion CAD for a delta of \$2.1 billion CAD in favour of the Interconnected Island Option.

5.3.1 Sensitivity Analysis of CPW

The Navigant report has conducted an in depth sensitivity analysis indicating the CPW based selection would not change under a large range of scenarios. These are illustrated in Figure 5.2.

Using the simplified approach the following sensitivity analysis was completed:

Scenario	Interconnected Island Scenario	Isolated Island Scenario	Difference
Base Case	6.8 B\$	9.5 B\$	2.7 B\$
Fuel at growth rate 50% of expected increase -> unit cost of Thermal of 170\$/MWh	6.2 B\$	6.9 B\$	0.7 B\$
Fuel at growth rate 150% of expected increase -> unit cost of Thermal of 355\$/MWh	13.5 B\$	7.8 B\$	5.7 B\$
+20% to Capital Cost of Muskrat Falls and LIL -> unit cost 155\$/MWh	7.6B\$	9.5B\$	1.9 B\$
With Energy Conservation for Isolated Option (750 GWh at 40\$/MWh)	6.8 B\$	7.9 B\$	1.1 B\$
With Energy Conservation for Isolated Option (750 GWh at 40\$/MWh) and Thermal Cost of 185 \$/MWh	7.2 B\$	7.2 B\$	0 B\$

The analysis shows that the preference is not particularly sensitive to an increase in Muskrat Falls and LIL project costs, but relatively sensitive to projected fuel costs. Aggressive conservation can play a very significant role in bridging the gap between the two options as well.

Notes:

- The CPW analysis is slightly biased in that a number of thermal resources are put on line in the later years when their cost cannot be fully amortized, reversely the study duration coincides exactly with the Labrador Transmission Link design life.
- If gas generation was developed at substantially less cost than 185 \$/MWh, which is very likely, then the Interconnected Island Scenario would be much more competitive.



5.4 SCHEDULE

5.4.1 Timing of Project Development

It was not possible to verify the timing of the inclusion of various capacity based assets since a review of the Loss of Load Hours (LOLH) cannot be performed. It is presumed that the timing of the asset deployment is adequate. MHI-Nalcor-13 illustrates this balance.

5.4.2 Individual Project Development Schedule

The indicated development times:

Facility	Development time from release date to in-service date (months)
Muskrat Falls HEF	
Labrador Island Link	60
Wind Farm	30
Island Pond HEF	42
Portland Creek HEF	32
Round Pond HEF	33
CCCT	36
CT	36

One of the major unknowns in the case of the isolated island projects is the permitting time frame which may increase the development durations suggested by Nalcor. For example the Round Pond schedule estimate comes directly out of the 1989 report, and it is doubtful the same allowance for environmental reviews was allotted two decades ago. A development in less than 3 years from initiation, including permitting and construction is extremely aggressive.

5.4.3 IPR Team Review

The IPR Team was of the opinion "that the Project Schedule has been developed in accordance to an agreed process and identifies the critical path and the correct sequence of key events." The schedule documentation indicates a quality of planning and scheduling appropriate for Gate 2. The IPR Team noted a number of schedule concerns such as the duration of Phase 3, the potential delays in EA release, and a significant level of time-risk exposure. However, they also indicated schedule risk mitigation steps had been taken, such as early turbine model tests and aggressive early construction programs. Again the IPR Teams focus was on the interconnected island option.

5.4.4 Environmental Assessment

The environmental assessment process is a key schedule item for which a sufficient schedule allowance should be made regardless of the option pursued. The permitting time frame remains an area of significant risk & uncertainty. Clarity in the project definition is of the utmost



importance to avoid long permitting delays. It is believed that the inclusion or non-inclusion of Gull Island renders the project's environmental impact assessment more difficult.

The clarity of information as the project progresses through the EA process is paramount.

DRAFT



SECTION 6.0 - CONCLUSION AND RECOMMENDATIONS

6.1 CONCLUSIONS

The study performed by Navigant Consulting for Nalcor Energy, found that the Muskrat Falls (MF) and Labrador-Island Link (LIL) option represents the lowest-cost option for consumers in Newfoundland. Knight Piésold Ltd. has performed a high level review and generally agrees with Navigant Consulting's findings and those presented by Nalcor Energy. However, there are large gaps in the information supplied that would temper that recommendation, in some instances the options compared may be sub-optimal. Furthermore there may be a larger role for gas within Newfoundland; and any readily accessible gas resource on the island could tip the CPW balance in favour of an isolated island scenario.

Knight Piésold has found that:

- The demand projections methodologies are reasonable and the results have been accepted as presented.
- Demand side management results were not included and could have a measurable impact. Its bearing on the overall supply selection should be to be demonstrated by Nalcor.
- The Isolated Island Option does not integrate as much wind or small hydro into consideration as may be possible; however the development of these renewable resources would not alleviate the requirement for the development of firm thermal resources in the future under the Isolated Island Option. The projected ratio of island renewable resources to overall thermal based generation resources is insufficient to compete with the interconnected island option.
- Nalcor and Navigant excluded natural gas generation in the generation expansion alternatives on the basis that natural gas was not yet available on the island and there were no firm plans to bring natural gas to the island. However, natural gas within a larger development plan of Newfoundland and Labrador at current projected market rates could be cost competitive with MF and the LIL (i.e. the Interconnected Island Option).

6.2 RECOMMENDATIONS

6.2.1 Criteria Definition

It would be helpful to develop a less succinct definition of the criteria that addresses the temporal or probabilistic aspect of the energy criteria and the basis for the selected LOLH capacity criteria.

6.2.2 Less Information, but More Clarity in Project Definitions

There is a need to provide a clear description of the proposed infrastructure without references to outdated reports or notification about innumerable changes, the material drowns out what is truly been proposed. In the case of the LIL almost no information has been provided about what exactly has been proposed and costed out. A summary list of the infrastructure components and the rough associated cost will give confidence of what was accounted for and a better understanding of the appropriateness.

6.2.3 Comprehensive documentation

Comprehensive documentation should be prepared covering:

- The overall economic evaluation, and
- The isolated island resource options.

6.2.4 Bearing the Cost of the MF and LIL Development (i.e. Alternative 1 – Interconnected Island Option)

There are a number of costs that could be borne by the consumer that are carried in the current MF and LIL proposals. The weight of these costs and how they are carried forward to the consumer will need to be closely monitored. For example:

- The cost of the Churchill Falls-Muskrat Falls transmission line has been included in the Muskrat Falls capital cost; while this was done to alleviate and reduce the supply risk should Muskrat Falls fail to commission on time, it is likely that the line would be utilized to export power in the early stages when all the power generated at the site may not be required by the Newfoundland consumers. The inclusion or non-inclusion may warrant a separate review if the cost is to be borne by Newfoundland customers.
- The optimization of the Muskrat Falls project has not been reviewed since 1998, in light of new project configurations and energy valuations a revision may be warranted (both in terms of installed capacity and height of infrastructure and assuming no development of Gull Island).
- Delaying the development of the Muskrat Falls (MF) and Labrador-Island Link (LIL) was not considered in the Navigant summary report on Decision Gate 2, a phased development of MF may also be worth considering, if exports are not permitted. Obviously, if exports of excess power are permitted and viable then the MF and LIL option will look even more attractive if these benefits trickle down to the Newfoundland consumer in terms of reduced electricity rates.

This report has been prepared with very limited access to the latest costing information, which is still classified as "confidential" by Nalcor. It is strongly recommended that this report be updated once this "classified" information is released to the public, and when the Manitoba Hydro International Report is made public by the Board.

**SECTION 7.0 - CERTIFICATION**

This report was prepared, reviewed and approved by the undersigned.

Prepared:

Boris Fichot, P.Eng.
Senior Engineer

Reviewed:

Sam Mottram, P.Eng.
Manager - Power Services

Approved:

Jeremy Haile, P.Eng.
President

This report was prepared by Knight Piésold Ltd. for the account of the Consumer Advocate of Newfoundland and Labrador. The material in it reflects Knight Piésold's best judgement in light of the information available to it at the time of preparation. Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, is the responsibility of such third parties. Knight Piésold Ltd. accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions, based on this report. This numbered report is a controlled document. Any reproductions of this report are uncontrolled and may not be the most recent revision.

TABLE 2.1
CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
PROJECT NAME
TWO GENERATION EXPANSION ALTERNATIVES - HIGHLEVEL REVIEW
DOCUMENT REVIEW

Print Oct/13/11 10:50:40

	Relevance	Reviewed	Notes:
Nalcor Main Submission			
Synopsis of 2010 Generation Expansion Decision	High	Yes	
Introduction			Does not cover all material
Generation Expansion Analysis			Strategist is industry standard
Reliability Criteria			Selected without sensitivity analysis presented
Generation Expansion Inputs			Does not cover all material
Generation Expansion Plans			Timeline framework biased towards LIL
Appendix A: Natural Resources News Release			Reference Question
Appendix B: MF Technical Note			Design history & specific Technical Information and Study References
Appendix C: LIL Technical Note			Design History and some Specific Technical Information and Study References
Nalcor Exhibits			
Exhibit 01 - Planning Load Forecasts	High	Yes	Accepted in Energy Plan, Consistent with Canadian Forecasts
Exhibit 02 - Load Shape	Medium	Yes	Based on Historical
Exhibit 03 - Nalcor Inflation Escalation Forecast	High	Yes	Close to 2% Overall, Resource selection ranking not particularly affected
Exhibit 04 - Nalcor Fuel Oil Price Forecast	High	Yes	Consistent with
Exhibit 05 - Capital Costs	High	Yes	Reviewed in KP Report
Exhibit 06 - Hydro PPA + HVDC Analysis	High	Yes	Basis for energy of Infeed? (average, firm, statistical)
Exhibit 07 - Service Life Retirement	High	Yes	Industry standard
Exhibit 08 - Opex Costs	High	Yes	Generally High in Ratio to Capital
Exhibit 09 - Thermal Units Heat Rates	Medium	Yes	Industry standard
Exhibit 10 - Energy Forecasts Hydro Wind	Low	Yes	No background, pattern useful, winter generation thermal component.
Exhibit 11 - Asset Maintenance	Low	Yes	
Exhibit 12 - Forced Outage Rates	Medium	Yes	Reflected in Capacity Factors
Exhibit 13 - Unit Capacities	High	Yes	Existing resources, control over non-Nalcor assets unclear
Exhibit 14 - Generation Expansion Plan_2010 PLF	High	Yes	Schedule of strategies, balance of energy demand unclear (firm, average, statistical)
Exhibit 15 - PWC Finance Summary	Medium	Yes	No inclusion of LIL
Exhibit 16 - Generation Planning Issues 2010	High	Yes	Summary of projects, delay of MF impact on LIL for reliability
Exhibit 17 - Water Management Agreement 2009	Low	No	Energy Calculation Elsewhere
Exhibit 18 - HVDC Interconnection 1998	High	Yes	From 1998
Exhibit 19 - Muskrat Falls Feasibility 1999	High	Yes	Not final arrangement, focus on Variant 7 (diversion tunnels, north variant), covers hydrology. Project optimization was carried over from previous study despite separate configuration. North Spur Stabilization
Exhibit 20 - Independent Analysis 2010	Low	Yes	"team misaligned on several key project elements which presents risks", labour shortages
Exhibit 21 - Project Review (Summary)_Gate 2	Low	Yes	labour and staffing plan, governance
Exhibit 22 - Project Review (Detailed)_Gate 2	Medium	Yes	Acceptance of optimization parameters, governance issues
Exhibit 23 - HVDC Link History	Medium	Yes	History
Exhibit 24 - Island Transmission Outlook	Low	Yes	
Exhibit 25 - Letter to Board July 12_2011	Low	Yes	Wind power PPA structure, replacement cost
Exhibit 26 - NLH Outage Rates Schedule	Low	Yes	% reflected in capacity factors
Exhibit 27 - PLF Summary 2010	Medium	Yes	Basis for load forecast
Exhibit 28 - PUB Letter July 12_2011	Medium	Yes	Report on Holyrood refurbishment
Exhibit 29 - Cost Effectiveness of supply power from LB to Island	Low	Yes	December 1980 Report on Cost Effectiveness, Scheduling Criteria
Exhibit 30 - LCP Design Progress	Medium	Yes	
Exhibit 31 - LPC Cost Progress	High	Yes	Variant 10, Class 4 Cost Estimate
Exhibit 32 - Financial Model Input 2011	Low	Yes	
Exhibit 33 - Ocean Currents	Low	No	
Exhibit 34 - Review of Fishing Equipment	Low	No	
Exhibit 35 - Iceberg Cable Risk	Low	No	
Exhibit 36 - Response to PUB Letter Muskrat Price	High	Yes	Basis for Cost of Service Price
Exhibit 37 - SOBI Decision Recommendation	High	Yes	Seabed Crossing vs. Tunnel / Conduit Crossing, Have Technical Uncertainties, Potential Cost Increases 80 M\$
Exhibit 38 - Muskrat Falls North Spur	Medium	Yes	
Exhibit 39 - Muskrat Piezometers	Low	No	
Exhibit 40 - Muskrat Piezometers2	Low	No	
Exhibit 41 - Muskrat Piezometers3	Low	No	
Exhibit 42 - 2009 Planning Review	High	No	2009, System, Does not discuss criteria
Exhibit 45 - Load Forecast Regressions	Medium	No	Too Cryptic
Exhibit 46 - PLF Key Forecast Units	Medium	No	
Exhibit 47 - Island Link Overview	High	Yes	History
Exhibit 48 - HVDC Link Reliability Study	Low	No	1981 Reliability Study
Exhibit 49 - Estimating Process Overview	Medium	No	



Exhibit 50 - PMF Estimate	Low	No	1999 - 21,900 m3/a + 5,000 with Upper Basin Discharge
Exhibit 51 - PMF Report 2	Low	No	
Exhibit 52 - Island Pond-Granite Canal Cost Update	Low	No	1997 - Cost
Exhibit 53 - Island Pond Feasibility 1988	Low	No	
Exhibit 54 - Bay D'Espoir Flood Analysis	Low	No	1985 - System
Exhibit 55 - Turbines and Transformers	Low	Yes	4 Kaplan, Lees Complex
Exhibit 56 - New Dawn Agreement	Medium	Yes	Province - Nalcor - Innu Nation, payment terms to Innu Nation
Exhibit 57 - HVDC Cable Reliability	Low	Yes	1985 - Reliability, PDF for Failures
Exhibit 58 - Total Island interconnected Load	Medium	Yes	Historical Island Load
Exhibit 59 - Preliminary Transmission System Analysis	High	Yes	Muskrat Falls to Churchill Falls
Exhibit 60 - Island Pond Hydro Pre-Feasibility Study	Medium	Yes	1986, Regulated system
Exhibit 61 - Wind Integration into the Island System	Medium	Yes	2004 - water management, frequency considerations and transmission limitations, 80 MW cap no spill, 130 no technical repercussions
Exhibit 62 - Key Regression Equations	Low	No	Too Cryptic
Exhibit 63 - Provincial Economic Data	Medium	No	
Exhibit 64 - Rural Island Interconnected Loads	Low	No	
Exhibit 65 - Hollyrood Life Extension Study	Medium	No	Hatch, 2011 Marine Terminal
Exhibit 66 - Hollyrood Emissions Reduction Study	Low	No	Alstom, 2002, Description, Fuel
Exhibit 67 - Hollyrood MCC Assessment	Low	No	Stantec, 2009 Arc-Flash Hazard Analysis
Exhibit 68 - Hollyrood Air Emissions	Medium	Yes	Acres 2004, Cost Comparison
Exhibit 69 - Island Pond Hydro - Geotech	Low	No	
Exhibit 70 - NLD Hydro 2010 Expansion Analysis	Medium	Yes	To Check Balance
Exhibit 71 - Transmission Line Meteorological Study	Low	No	1973
Exhibit 72 - Transmission Line Meteorological Study 2	Low	No	1975
Exhibit 73 - Transmission Line Ice and Wind Loading	Low	No	1974
Exhibit 74 - Transmission Line Meteorological Evaluation 1974	Low	No	
Exhibit 75 - Weather Study 1977-78	Low	No	
Exhibit 76 - Weather Study 1978-79	Low	No	
Exhibit 77 - Weather Study 1979-80	Low	No	
Exhibit 78 - Weather Study 1980-81	Low	No	
Exhibit 79 - Weather Study 1981-82	Low	No	
Exhibit 80 - Weather Study 1982-83	Low	No	
Exhibit 81 - Weather Study 1983-84	Low	No	
Exhibit 82 - Weather Study 1984-85	Low	No	
Exhibit 83 - Weather Study 1985-86	Low	No	
Exhibit 84 - Weather Study 1986-87	Low	No	
Exhibit 85 - Transmission Line Reliability Study	Low	No	1996, Avalon and Connaigre Peninsulas
Exhibit 86 - Transmission Line Ice Monitoring	Low	No	Ice monitoring
Exhibit 87 - Transmission Climate Loadings	Low	No	
Exhibit 88 - Transmission Atmospheric Icing	Low	No	
Exhibit 89 - Transmission upgrading of 230 kV lines	Low	No	
Exhibit 90 - Transmission Wind and Ice Loading	Low	No	
Exhibit 91 - HVDC In-Cloud Icing	Low	No	
Exhibit 92 - Meteorological Load Review 2008	Medium	Yes	2008 Summary, from Gull Island
Exhibit 93 - Transmission Icing Models	Low	No	
Exhibit 94 - HVDC Ice Loadings	Low	No	
Exhibit 95 - Transmission In-Cloud Icing in Mountains	Low	No	
Exhibit 96 - Transmission Line Freezing Rain	Low	No	
Exhibit 97 - Transmission Line Weather 2011	Low	No	
Exhibit 99 - NLD Hydro Generation Expansion Analysis	High	Yes	to Check Balance
Exhibit 100 - Output from Isolated and Interconnected Facilities	High	Yes	to Check Balance
Exhibit 101 - Independent Supply Decision Review	High	Yes	Navigant Report Executive summary

Nalcor Responses to RFIs

MHI-Nalcor - 005 - Batch 01 RFI Responses July 26-11	Medium	Yes	AFUDC
MHI-Nalcor - 010 - Batch 01 RFI Responses July 26-11	Low	Yes	No obligation to renew Wind PPA
MHI-Nalcor - 022 - Batch 01 RFI Responses July 26-11	Low	Yes	
MHI-Nalcor - 024 - Batch 01 RFI Responses July 26-11	Low	Yes	Reliability concerns of HVDC
MHI-Nalcor - 026 - Batch 01 RFI Responses July 26-11	Low	Yes	Cost of public consultation not material
MHI-Nalcor - 029 - Batch 01 RFI Responses July 26-11	Low	Yes	Immaterial
MHI-Nalcor - 031 - Batch 01 RFI Responses July 26-11	Low	Yes	Global Insight revised reports for DG 3
MHI-Nalcor - 032 - Batch 01 RFI Responses July 26-11	Low	Yes	10% ROR Basis
MHI-Nalcor - 033 - Batch 01 RFI Responses July 26-11	Low	Yes	Royalty to Innu and Water Power royalty included
MHI-Nalcor - 007 - Batch 02 RFI Responses July 27-11	High	Yes	HVDC Capital Cost Composition
MHI-Nalcor - 014 - Batch 02 RFI Responses July 27-11	Medium	Yes	HVDC, All hardware included
MHI-Nalcor - 023 - Batch 02 RFI Responses July 27-11	Low	Yes	Further optimization in Phase 3
MHI-Nalcor - 025 - Batch 02 RFI Responses July 27-11	Medium	Yes	O&M estimates by Nalcor not in DC1010
MHI-Nalcor - 027 - Batch 02 RFI Responses July 27-11	Low	Yes	EA costs of HVDC
MHI-Nalcor - 030 - Batch 02 RFI Responses July 27-11	Medium	Yes	MF1010 quantities, unit costs and schedule by Nalcor
MHI-Nalcor - 034 - Batch 02 RFI Responses July 27-11	Low	Yes	Owner's cost fixed percentage for Island Pond



MHI-Nalcor - 008 - Batch 03 RFI Responses and Exhibits 38-41	Medium	Yes	Exchange Rates
MHI-Nalcor - 018 - Batch 03 RFI Responses and Exhibits 38-41	Medium	Yes	Cost of Service vs. PPA
MHI-Nalcor - 019 - Batch 03 RFI Responses and Exhibits 38-41	High	Yes	No definitive design report
MHI-Nalcor - 020 - Batch 03 RFI Responses and Exhibits 38-41	High	Yes	Effectiveness of sump pump system, Exhibit 19, 38, 39, 40, 41
MHI-Nalcor - 021 - Batch 03 RFI Responses and Exhibits 38-41	Medium	Yes	No provision for future capacity.
MHI-Nalcor - 035 - Batch 03 RFI Responses and Exhibits 38-41	Low	Yes	Cost of Service vs. PPA
MHI-Nalcor - 004 - Batch 04 RFI Responses August 5-11	Low	Yes	No update to Island, Portland, Round Cost Estimate
MHI-Nalcor - 006 - Batch 04 RFI Responses August 5-11	Low	Yes	Cost Estimate Level of Detail Appropriate
MHI-Nalcor - 009 - Batch 04 RFI Responses August 5-11	Low	Yes	Holyrood consideration not further lower cost of isolated island options
MHI-Nalcor - 011 - Batch 04 RFI Responses August 5-11	Low	Yes	Retirement of Holyrood site. Estimated at 7 M\$ for conversion to synchronous condenser.
MHI-Nalcor - 048 - Batch 04 RFI Responses August 5-11	Low	Yes	MF1330 not included
MHI-Nalcor - 053 - Batch 04 RFI Responses August 5-11	Low	Yes	HVDC design voltage 320 kV
MHI-Nalcor - 054 - Batch 04 RFI Responses August 5-11	Low	Yes	100 % of Capital Allocated to CPW
PUB-Nalcor - 001 - Batch 04 RFI Responses August 5-11	Low	Yes	Exhibit 37
PUB-Nalcor - 002 - Batch 04 RFI Responses August 5-11	Low	Yes	Exhibit 35
PUB-Nalcor - 003 - Batch 04 RFI Responses August 5-11	Low	Yes	July 18, 2011 Presentation Questions
PUB-Nalcor - 004 - Batch 04 RFI Responses August 5-11	Low	Yes	July 18, 2011 Presentation Questions
MHI-Nalcor - 028 - Batch 05 RFI Responses August 8-11	Medium	Yes	DG2 9.5 M\$ for land owner easements, expropriations, land use royalties
MHI-Nalcor - 037 - Batch 05 RFI Responses August 8-11	Medium	Yes	Planning Criteria Exhibit 42
MHI-Nalcor - 040 - Batch 05 RFI Responses August 8-11	High	Yes	AC Power system integration, isolated island option, Exhibit 24.
MHI-Nalcor - 049 - Batch 06 RFI Responses Aug 9-11	High	Yes	Fuel cost, operating cost, ppas, AFUDC rate used is 7.53%
MHI-Nalcor - 049 - Batch 06 MHI-Nalcor-49.1 FuelCosts.xls	High	Yes	
MHI-Nalcor - 049 - Batch 06 MHI-Nalcor-49.2 OperatingandPPACosts.xl	High	Yes	
MHI-Nalcor - 049 - Batch 06 MHI-Nalcor-49.3 AFUDC and Escalation.xls	High	Yes	
MHI-Nalcor - 015 - Batch 07 RFI Responses August 10-11	Low	Yes	HVDC plant performance criteria not defined, reliability in Exhibit 29
MHI-Nalcor - 017 - Batch 07 RFI Responses August 10-11	Low	Yes	Synchronous condenser operation for 2 units when soldier Pond commissioned.
MHI-Nalcor - 027 - Batch 07 RFI Responses August 10-11	Low	Yes	EA costs (23 M\$, 15 spent)
MHI-Nalcor - 039 - Batch 07 RFI Responses August 10-11	Medium	Yes	AC integration studies for HVDC underway. Objectives listed.
MHI-Nalcor - 046 - Batch 07 RFI Responses August 10-11	Low	Yes	Wind integration - Exhibit 25.
MHI-Nalcor - 050 - Batch 07 RFI Responses August 10-11	Medium	Yes	Escalators Exhibit 3 Description
PUB-Nalcor - 005 - Batch 07 RFI Responses August 10-11	High	Yes	Island Average Domestic Rate Projections (Slide 26)
Response to Board - Question 4 - Batch 07 RFI Responses August 10-11	High	Yes	Combustion Turbine Data and Cost Estimate, Note Exchange Rate. CCCT \$1,325 2008 USD per kW and CT \$1,266 2010 USD per kW
MHI-Nalcor - 001 - Batch 08 RFI Responses August 10-11	Medium	Yes	CPW composite costs Excel file Exhibit 14.
MHI-Nalcor - 038 - Batch 08 RFI Responses August 10-11	Low	Yes	HVDC Converter Station specifications section 6 Exhibit 30.
MHI-Nalcor - 043 - Batch 08 RFI Responses August 10-11	Medium	Yes	SOBI Feasibility - Exhibits 33-35, CE-40-44.
MHI-Nalcor - 044 - Batch 08 RFI Responses August 10-11	Low	Yes	Power system reliability study, use traditional system planning procedures. Exhibit 24.
MHI-Nalcor - 047 - Batch 08 RFI Responses August 10-11	Low	Yes	CT and CCCT feasibility, See Q4.
MHI-Nalcor - 051 - Batch 08 RFI Responses August 10-11	Low	Yes	Projected GWh/yr and \$CAD(2010)/yr by fuel type
MHI-Nalcor - 055 - Batch 08 RFI Responses August 10-11	Low	Yes	Newfoundland and Labrador Hydro 2010 Long Term Planning Forecast Exhibit 27, 45, 46
MHI-Nalcor - 056 - Batch 08 RFI Responses August 10-11	Low	Yes	Historic sales and generation, MHI-Nalcor 55
MHI-Nalcor - 057 - Batch 08 RFI Responses August 10-11	Low	Yes	Thermal Generation life extensions at Holyrood Exhibit 43
PUB-Nalcor - 006 - Batch 08 RFI Responses August 10-11	Medium	Yes	Public policy initiatives list that influence two alternatives
MHI-Nalcor - 041 - Batch 09 RFI Responses August 11-11	Low	Yes	CPW derived in Strategist: modules, objective function: 100% "minimization of utility cost." Fuel cost sensitivity 4 scenarios.
MHI-Nalcor - 042 - Batch 09 RFI Responses August 11-11	Low	Yes	Strategist Inputs List of References
MHI-Nalcor - 060 - Batch 09 RFI Responses August 11-11	Low	Yes	MHI-Nalcor-41
Response to Board - Question 4 - Batch 09 RFI Responses August 11-11	Medium	Yes	PPA vs COS
MHI-Nalcor - 013 - Batch 10 RFI Response August 11-11	Medium	Yes	Load balance MHI-Nalcor-13a and MHI-Nalcor-13b
MHI-Nalcor - 016 - Batch 11 RIF Responses August 12-11	Low	Yes	Selection based on constraint violation.
MHI-Nalcor - 045 - Batch 11 RIF Responses August 12-11	Low	Yes	MHI-Nalcor-44
MHI-Nalcor - 036 - Batch 12 RFI Responses August 16-11	Low	Yes	Unredacted costs CE44, CE 48, CE-49
MHI-Nalcor - 059 - Batch 12 RFI Responses August 16-11	Low	Yes	Insurance based on replacement of assets, TL self insured. 0.03 per 100\$.
MHI-Nalcor - 052 - Batch 13 RFI Responses August 17-11	Low	Yes	Environmental mitigation costs (Lists Categories not \$)
Response to Board - Question 3 - Batch 13 RFI Responses August 17-11	Medium	Yes	Risk Analysis, Confidential Exhibit - 52
MHI-Nalcor - 058 - Batch 14 RFI Responses August 19	Low	Yes	Exhibit 15 clarifications
MHI-Nalcor - 012 - Batch 15 RFI Responses August 24-11	Medium	Yes	Operating costs for Labrador Island Link
MHI-Nalcor - 069 - Batch 15 RFI Responses August 24-11	Low	Yes	Refurbishment provisions of LIL over 50 years.
MHI-Nalcor - 073 - Batch 15 RFI Responses August 24-11	High	Yes	Benchmark cost estimates - Confidential Exhibit 51
MHI-Nalcor - 077 - Batch 15 RFI Responses August 24-11	Low	Yes	Confidential Exhibit CE-54, Floods
MHI-Nalcor - 094 - Batch 15 RFI Responses August 24-11	Low	Yes	SOBI Reliability Exhibit 57, 1985 Report
MHI-Nalcor - 010 - Batch 15 RFI Responses August 24-11	Low	Yes	Exhibit 47
MHI-Nalcor - 018 - Batch 16 RFI Responses August 26-11	Low	Yes	Government's 25,000 tons per year not exceeded with Holyrood at 100%
MHI-Nalcor - 019 - Batch 16 RFI Responses August 26-11	Low	Yes	Government's 25,000 tons per year not exceeded with Holyrood at 100%
MHI-Nalcor - 063 - Batch 17 RFI Responses August 29-11	Low	Yes	Churchill to MF optimized at 345 kV, Exhibit 59
MHI-Nalcor - 070 - Batch 17 RFI Responses August 29-11	Medium	Yes	Custom indicas for converter and equipments not provided.
MHI-Nalcor - 076 - Batch 17 RFI Responses August 29-11	Medium	Yes	Pumpwell for 10 year, no failure provisions. Final design to determine.
MHI-Nalcor - 090 - Batch 17 RFI Responses August 29-11	Low	Yes	Historical Sales - Exhibit 58
MHI-Nalcor - 091 - Batch 17 RFI Responses August 29-11	Low	Yes	Historical Sales - Exhibit 58



MHI-Nalcor - 093 - Batch 17 RFI Responses August 29-11	Low	Yes	Forecast Information - Exhibit 45
MHI-Nalcor - 095 - Batch 17 RFI Responses August 29-11	Low	Yes	Confidential Exhibit CE-55, RFP on Submarine Cable Design
PUB-Nalcor - 016 - Batch 17 RFI Responses August 29-11	Low	Yes	Rio Tinto increase production 100%, increase in Labrador Load
MHI-Nalcor - 085 - Batch 18 RFI Responses September 1-11	Low	Yes	Single Line Diagram (Soldiers Pond)
MHI-Nalcor - 066 - Batch 18 RFI Responses September 1-11	Low	Yes	Technical requirements for the 3 – 300 MVar Synchronous Condensers CE-10
MHI-Nalcor - 068 - Batch 18 RFI Responses September 1-11	Low	Yes	CE-04 synchronous condenser requirements
MHI-Nalcor - 061 - Batch 19 RFI Responses 02-September-11	Low	Yes	No operational based reliability report, forced outage rate of 0.89%
MHI-Nalcor - 072 - Batch 19 RFI Responses 02-September-11	Low	Yes	No mechanical fuse.
MHI-Nalcor - 078 - Batch 19 RFI Responses 02-September-11	Low	Yes	Hydrology for Round Pond
MHI-Nalcor - 087 - Batch 19 RFI Responses 02-September-11	Low	Yes	40% CF for wind basis.
MHI-Nalcor - 092 - Batch 19 RFI Responses 02-September-11	Low	Yes	historical demand information
PUB-Nalcor - 017 - Batch 19 RFI Responses 02-September-11	Low	Yes	1989 Exceedance of emissions cap.
MHI-Nalcor - 074 - Batch 20 RFI Responses 6-11	High	Yes	4,870 TWh. Installed capacity differ after Gull Island, Quebec River Diversion, and CF2. Nalcor does not intend to develop Muskrat Falls in isolation of Gull Island. 824MW design for Muskrat Falls optimum. No Quebec river diversion included.
MHI-Nalcor - 088 - Batch 20 RFI Responses 6-11	Low	Yes	Wind integration, Exhibit 61.
MHI-Nalcor - 103 - Batch 20 RFI Responses 6-11	Low	Yes	Synchronous condenser conversion at Holyrood in CE-61
MHI-Nalcor - 112 - Batch 20 RFI Responses 6-11	Low	Yes	Validation of Iceberg risks
MHI-Nalcor - 113 - Batch 20 RFI Responses 6-11	Low	Yes	Impact energy of Iceberg risks
MHI-Nalcor - 082 - Batch 21 RFI Responses September 7-11	Low	Yes	Detail on Round Pond HEP, none
MHI-Nalcor - 062 - Batch 22 RFI Responses September 9-11	Low	Yes	Calc of 320 kV minimum, maximum HVdc system losses has been set at 10%
MHI-Nalcor - 064 - Batch 22 RFI Responses September 9-11	Low	Yes	Single line diagram for Muskrat Falls is under development. Simplified attached.
MHI-Nalcor - 115 - Batch 22 RFI Responses September 9-11	Low	Yes	Regression equations for load forecast Exhibit 62
MHI-Nalcor - 079 - Batch 23 RFI Responses September 14-11	Low	Yes	CE-57 Island Pond Cost
MHI-Nalcor - 081 - Batch 23 RFI Responses September 14-11	Low	Yes	CE-58 Portland Creek Cost Backup
MHI-Nalcor - 114 - Batch 24 15 September 2011	Low	Yes	Exhibit 64, 46 and MHI-Nalcor 62
MHI-Nalcor - 116 - Batch 24 15 September 2011	Low	Yes	Exhibit 63
MHI-Nalcor - 109 - Batch 25 - 16 September 2011	Low	Yes	Exhibit 65, marine terminal life extensions would be substantially larger
MHI-Nalcor - 111 - Batch 25 - 16 September 2011	Low	Yes	Exhibit 67
MHI-Nalcor - 110 - Batch 26 - 16 September 11	Low	Yes	Exhibits 68 & 68
MHI-Nalcor - 080 - Batch 27 - RFI Responses - 20 September 2011	Low	Yes	Exhibit 69
MHI-Nalcor - 098 - Batch 27 - RFI Responses - 20 September 2011	Low	Yes	Exhibit 70, Corner Brook Co-Gen as Thermal Source
MHI-Nalcor - 104 - Batch 27 - RFI Responses - 20 September 2011	Low	Yes	kWh/bbl vs unit load (MW) for Holyrood
MHI-Nalcor - 075 - Batch 28 RFI Responses 21 September 2011	Low	Yes	CF interconnection has no impact
MHI-Nalcor - 108 - Batch 28 RFI Responses 21 September 2011	Low	Yes	Summary of starts per year for each Holyrood Unit
MHI-Nalcor - 089 - Batch 29 RFI Responses 23 September 2011	Medium	Yes	Wind penetration, Exhibit 61, 80 MW no spill, 130 MW spill. +100 MW by 2025.
MHI-Nalcor - 099 - Batch 29 RFI Responses 23 September 2011	Low	Yes	PPA Energy Tariff of \$75.82 /MWh in 2010\$ escalating at 2% annually
MHI-Nalcor - 101 - Batch 29 RFI Responses 23 September 2011	Low	Yes	ESP and FGD installations in their report are totaled at \$450 million. \$582 is 2010
MHI-Nalcor - 081 - Batch 29 RFI Responses 23 September 2011	Low	Yes	Navigant Report available
MHI-Nalcor - 082 - Batch 29 RFI Responses 23 September 2011	Low	Yes	Navigant Report available
PUB-Nalcor - 080 - Batch 30 RFI Responses 26 September 2011	Low	Yes	Navigant TOR
MHI-Nalcor - 002 - Batch 31 RFI Responses 27 September 2011	High	Yes	Sensitivity to reduced time frame. CPW preference of the Interconnected Scenario over the isolated Island Scenario is \$1,058 million.
MHI-Nalcor - 003 - Batch 31 RFI Responses 27 September 2011	High	Yes	Upper Churchill Power after 2041. Deferral of the interconnection would result in significantly higher rates for Island consumers between now and 2041. High risk and uncertainty.
MHI-Nalcor - 071 - Batch 31 RFI Responses 27 September 2011	Medium	Yes	Appendix A of Exhibit 97 loadings by area, design details not available
MHI-Nalcor - 080 - Batch 31 RFI Responses 27 September 2011	Low	Yes	Exhibit 98 - Studies for Island Pond Hydroelectric Project
MHI-Nalcor - 083 - Batch 32 RFI Responses 04 October 2011	Low	Yes	DC1210 – "HVDC Sensitivity Studies"

Other Resources

Report of the Joint Review Panel	High	Partial	Environmental Impact
Focusing Our Energy	Medium	Yes	2007 Energy Plan
Independent Supply Decision Review	High	Yes	Review of Options and Sensitivity Analysis

M:\1\03\00365\02\A\Report\Document Review Table.xlsx\Document Review

0	18OCT11	ISSUED WITH REPORT	BXF	SRM	JPH
REV	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D

**CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVES**

**HIGH LEVEL REVIEW REPORT
GENERATION PORTFOLIO SUMMARY**

Print: 10/14/11 8:14

Resource	Design Life (years)	2010 Capital Cost (M\$)	Capacity (MW)	Firm Generation (GWh)	Average Generation (GWh)	Capacity Factor	Capital Cost to Capacity Ratio (M\$/MW)	Capital Cost to Firm Generation Ratio (M\$/GWh)	Capital Cost to Average Generation Ratio (\$/GWh)	Estimated 2010 Energy Price on Sales Basis (\$/MWh)
Hydropower Project										
Muskrat Falls and Labrador Island Link	50	4,929	824	4,470	4,580	63%	5.98	1.10	1.08	131*
Island Pond Development	50	166.2	36	179	188	60%	4.62	0.93	0.88	85*
Round Pond Development	50	142.2	18	108	132	84%	7.90	1.32	1.08	99*
Portland Creek	50	89.9	23	99	142	70%	3.91	0.91	0.63	58*
Other Small Hydro	50									102**
Wind Power										
25 MW Wind Farm	20	58.1	25	NA	88	40%	2.32	NA	0.66	80*
Renewable Average										
Island Renewable Portfolio			152	386	725	54%				81
Thermal										
CCCT 170	30	206.2	170	1,340	1,340 894 447	90% 60% 30%	1.21	0.15	0.15	231* 243* 271*
GT 50	25	65.1	50	394	329	90%	1.30	0.17	0.20	276*
GT 50 - Capacity Payment			50	394		2%				130,000\$/MW
DSM										
Aggressive Agregated Strategies	NA	200	90	750	750	95%	2.22	0.27	0.27	40**
1/2 Aggressive Agregated Strategies	NA	100	45	375	375	95%	2.22	0.27	0.27	40**

Notes:

* KP Simplified Financial Analysis

** Navigant Report

0	09SEP11	ISSUED WITH REPORT 303-112/1-1	BXF	SRM	JPH
REV	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D

TABLE 5.2

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVESHIGH LEVEL REVIEW REPORT
BASIC FINANCIAL ANALYSIS - MF & LIL

Print: 11/11/11 16:52

Year of Development 2017

Financial

Interest Rate	0.0%
Discount rate	8.0%
2010 Energy Sale	130.7 \$/MWh
Energy Sale Escalation	2.0%

Analysis

Internal Rate of Return	8.0%
-------------------------	------

Asset

Greenfield CCCT	
Installed Capacity	824 MW
Capacity Factor	67.8%
Average Available Generation	4900.0 GWh
Life of Infrastructure	50 Years

Capital Cost

2010 Capital Cost \$ 4,974,531,656

		Distribution	LIL	LIL AFUDC	MF	MF AFUDC	TOTAL
Year -7	2010	3.3%	\$ 108,892,854	\$ 753,465	\$ 56,448,952		\$ 166,095,270
Year -6	2011	2.9%	\$ 19,106,627	\$ 1,191,996	\$ 125,789,166		\$ 146,087,789
Year -5	2012	13.4%	\$ 216,580,120	\$ 2,382,350	\$ 451,626,159		\$ 670,588,629
Year -4	2013	26.1%	\$ 506,473,481	\$ 55,615,766	\$ 792,206,676		\$ 1,354,295,922
Year -3	2014	24.0%	\$ 544,807,024	\$ 97,913,375	\$ 649,259,465		\$ 1,291,979,864
Year -2	2015	18.3%	\$ 426,213,841	\$ 142,120,932	\$ 482,150,585		\$ 1,050,485,359
Year -1	2016	11.3%	\$ 251,094,350	\$ 180,088,870	\$ 309,803,801		\$ 740,987,021
Year 0	2017	0.7%			\$ 34,078,555		\$ 34,078,555

Year	Life Year	Investment (\$)	Energy Sales (\$)	Operating Cost (\$)	Fuel Cost (\$)	Interest (\$)	Cash Flow (\$)	Cumulative Cash Flow (\$)
2010		166,095,270					-166,095,270	-166,095,270
2011		146,087,789					-146,087,789	-312,183,059
2012		670,588,629					-670,588,629	-982,771,688
2013		1,354,295,922					-1,354,295,922	-2,337,067,610
2014		1,291,979,864					-1,291,979,864	-3,629,047,474
2015		1,050,485,359					-1,050,485,359	-4,679,532,833
2016		740,987,021					-740,987,021	-5,420,519,855
2017	0	34,078,555	272,103,707	20,316,000			217,709,152	-5,202,810,703
2018	1		288,157,015	27,592,084			260,564,931	-4,942,245,772
2019	2		304,977,887	33,822,950			271,154,937	-4,671,090,835
2020	3		321,623,523	29,117,021			292,506,502	-4,378,584,333
2021	4		343,622,770	35,710,288			307,912,472	-4,070,671,860
2022	5		366,605,376	30,770,402			335,834,974	-3,734,836,886
2023	6		402,051,686	31,631,973			370,419,713	-3,364,417,174
2024	7		421,990,961	32,517,668			389,473,292	-2,974,943,881
2025	8		440,649,817	33,428,163			407,221,654	-2,567,722,227
2026	9		464,209,887	40,901,152			423,308,736	-2,144,413,491
2027	10		489,707,254	35,326,348			454,380,907	-1,690,032,585
2028	11		524,363,545	36,315,486			488,048,059	-1,201,984,526
2029	12		575,878,954	37,332,319			538,546,635	-663,437,891
2030	13		602,504,789	38,377,624			564,127,165	-99,310,726
2031	14		629,985,113	46,848,198			583,136,915	483,826,189
2032	15		658,263,036	40,556,859			617,706,176	1,101,532,365
2033	16		687,440,690	41,692,451			645,748,238	1,747,280,604
2034	17		717,543,165	42,859,840			674,683,325	2,421,963,928
2035	18		746,859,520	44,059,915			702,799,605	3,124,763,533
2036	19		775,268,226	53,661,593			721,606,633	3,846,370,166
2037	20		776,809,577	48,561,814			730,247,764	4,576,617,930
2038	21		807,362,660	47,885,544			759,497,115	5,336,115,045
2039	22		839,662,627	49,205,780			790,456,847	6,126,571,892
2040	23		871,179,914	50,583,542			820,596,372	6,947,168,264
2041	24		903,477,154	61,466,881			842,010,273	7,789,178,537
2042	25		936,767,068	53,455,877			883,311,191	8,672,489,728
2043	26		970,976,946	54,952,642			916,024,304	9,588,514,032
2044	27		1,006,283,006	56,491,316			948,791,691	10,538,305,723
2045	28		1,042,534,511	58,073,073			984,461,438	11,522,767,161
2046	29		1,079,860,220	70,410,119			1,009,450,102	12,532,217,262
2047	30		1,118,071,602	61,370,894			1,056,700,908	13,588,918,171
2048	31		1,157,545,909	63,089,073			1,094,456,836	14,683,375,006
2049	32		1,198,123,669	64,855,568			1,133,268,102	15,816,643,108
2050	33		1,237,639,599	66,671,523			1,170,968,075	16,987,611,183
2051	34		1,278,168,617	80,657,326			1,197,511,290	18,185,122,473
2052	35		1,319,853,761	70,457,399			1,249,396,362	19,434,518,835
2053	36		1,362,695,044	72,430,206			1,280,264,837	20,724,783,673
2054	37		1,405,503,879	74,458,252			1,331,045,627	22,055,829,300
2055	38		1,449,511,849	76,543,083			1,372,968,766	23,428,798,065
2056	39		1,494,717,936	92,397,290			1,402,320,647	24,831,118,712
2057	40		1,541,086,169	80,889,506			1,460,196,663	26,291,315,375
2058	41		1,588,609,815	83,154,412			1,505,455,403	27,796,770,779
2059	42		1,637,486,944	85,482,735			1,552,004,209	29,348,774,988
2060	43		1,687,824,417	87,876,252			1,599,948,166	30,948,723,153
2061	44		1,739,197,482	105,849,787			1,633,347,695	32,582,070,848
2062	45		1,792,096,727	92,866,217			1,699,230,510	34,281,301,357
2063	46		1,846,378,934	95,466,471			1,750,912,463	36,032,213,820
2064	47		1,902,191,740	98,139,532			1,804,052,208	37,836,266,028
2065	48		1,957,750,863	100,887,439			1,856,863,423	39,693,129,451
2066	49		2,013,424,621	121,264,288			1,882,160,334	41,585,289,785
2067	50		2,069,249,252	106,616,232			1,962,633,020	43,547,922,805

M:\1103\00365\02\A\Cost Tables\Financial Analysis - BXF2011-11-01.xlsm\MF and LIL

Notes:

- LIL costs and AFUDC and MF Cost as reflected in Naicor Exhibit 5e and 5f
- Energy Demand over Link as Forecasted in Exhibit 100
- Operating cost from Exhibit 8

REV	DATE	DESCRIPTION	BY	CHKD	APPD
0	140011	ISSUED WITH REPORT	BY	BRM	JPH

TABLE 5.3

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVESHIGH LEVEL REVIEW REPORT
BASIC FINANCIAL ANALYSIS - 170 MW CCCT (90% CF)

Print 11/1/11 10:52

Year of Development 2025

Financial
Interest Rate 0.0%
Discount rate 8.0%
2010 Energy Sale 231.0 \$/MWh
Energy Sale Escalation 2.0%

Analysis
Internal Rate of Return 10.0%

Asset Greenfield CCCT
Installed Capacity 170 MW
Capacity Factor 90.0%
Average Available Gen 1340.3 GWh
Generation Assumed 1340.3 GWh
Life of Infrastructure 30 Years

Capital Cost
2010 Capital Cost \$ 206,187,000
Relevant Index CCCT Plant Construction
AFUDC 7.53%

Cost	Distribution	2010	2025	AFUDC	Total	
Year -4	2021					
Year -3	2022					
Year -2	2023	13.7%	\$ 28,326,821	\$ 35,436,853	\$ 1,334,198	\$ 38,771,051
Year -1	2024	53.9%	\$ 110,860,926	\$ 141,458,542	\$ 8,064,774	\$ 149,553,316
Year 0	2025	32.5%	\$ 66,999,152	\$ 87,232,896	\$ 17,314,543	\$ 104,547,440

O&M Cost 2010 2010
Fixed 9,220 \$/MW 1,567,400
Variable 5.32 \$/MWh 7,130,290
Escalation 2.8%

Year	Life Year	Investment	Energy Sales	Operating Cost	Fuel Cost	Interest	Cash Flow	Cumulative Cash Flow
		(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
2010						0	0	0
2011						0	0	0
2012						0	0	0
2013						0	0	0
2014						0	0	0
2015						0	0	0
2016						0	0	0
2017						0	0	0
2018						0	0	0
2019						0	0	0
2020						0	0	0
2021						0	0	0
2022						0	0	0
2023		38,771,051				0	-38,771,051	-38,771,051
2024		149,553,316				0	-149,553,316	-188,324,367
2025	0	104,547,440				0	-104,547,440	-290,871,807
2026	1		425,020,879	13,528,874	382,207,703	0	29,283,302	-261,588,505
2027	2		433,521,297	13,908,710	389,338,444	0	30,274,143	-231,314,362
2028	3		442,191,722	14,298,154	397,895,332	0	29,968,236	-201,316,126
2029	4		451,035,557	14,698,502	406,452,221	0	29,884,833	-171,431,292
2030	5		460,056,268	15,110,080	413,582,982	0	31,363,246	-140,068,047
2031	6		469,257,393	15,533,142	422,139,851	0	31,584,400	-108,483,646
2032	7		478,642,541	15,968,070	430,696,740	0	31,977,732	-76,505,915
2033	8		488,215,392	16,416,176	439,253,629	0	32,546,588	-43,959,327
2034	9		497,979,700	16,874,801	447,810,518	0	33,294,382	-10,664,945
2035	10		507,939,294	17,347,295	456,367,406	0	34,224,592	23,559,647
2036	11		518,098,080	17,833,020	466,350,443	0	33,914,617	57,474,264
2037	12		528,460,041	18,332,344	474,907,332	0	35,220,365	92,694,629
2038	13		539,029,242	18,845,660	484,890,369	0	35,263,223	127,957,852
2039	14		549,809,827	19,373,328	494,873,406	0	35,563,093	163,550,945
2040	15		560,806,024	19,915,781	504,856,443	0	36,033,799	199,584,744
2041	16		572,022,144	20,473,423	514,839,480	0	36,709,241	236,293,985
2042	17		583,462,687	21,046,679	524,822,517	0	37,593,391	273,887,376
2043	18		595,131,839	21,635,986	534,805,554	0	38,660,299	312,577,674
2044	19		607,034,475	22,241,793	546,214,740	0	38,577,943	351,155,617
2045	20		619,175,165	22,864,584	557,623,925	0	38,686,677	389,842,293
2046	21		631,558,668	23,504,771	569,033,110	0	39,020,787	428,863,080
2047	22		644,189,842	24,162,905	580,442,295	0	39,584,642	468,447,722
2048	23		657,073,638	24,839,466	591,851,480	0	40,382,682	508,830,414
2049	24		670,215,111	25,534,871	603,260,665	0	41,419,475	550,249,889
2050	25		683,619,413	26,249,951	614,669,850	0	42,669,812	592,919,701
2051	26		697,291,802	26,984,949	627,505,184	0	42,801,669	635,751,189
2052	27		711,237,638	27,740,528	640,340,517	0	43,156,593	678,907,782
2053	28		725,462,391	28,517,263	653,175,850	0	43,769,278	722,677,060
2054	29		739,971,638	29,315,748	666,011,184	0	44,644,709	767,321,769
2055	30		754,771,071	30,136,587	678,846,517	0	45,787,967	813,109,716
2056						0	0	813,109,716
2057						0	0	813,109,716
2058						0	0	813,109,716
2059						0	0	813,109,716
2060						0	0	813,109,716
2061						0	0	813,109,716
2062						0	0	813,109,716
2063						0	0	813,109,716
2064						0	0	813,109,716
2065						0	0	813,109,716
2066						0	0	813,109,716
2067						0	0	813,109,716

M:\103\00365\02\A\Cost Tables\Financial Analysis - BXP2011-11-01.xlsm\170MW CCCT (90% CF)

REV	DATE	DESCRIPTION	BY	CHKD	APPD
0	08/21/11	ISSUED WITH REPORT 2011-11-01	BXP	BPM	JPR

TABLE 5.4

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVESHIGH LEVEL REVIEW REPORT
BASIC FINANCIAL ANALYSIS - 170 MW CCCT (60%CF)

Print: 11/11/11 16:52

Year of Development 2025

Financial

Interest Rate 0.0%
 Discount rate 8.0%
 2010 Energy Sale \$43.0 \$/MWh
 Energy Sale Escalation 2.0%

Analysis

Internal Rate of Return 10.1%

Asset

Greenfield CCCT
 Installed Capacity 170 MW
 Capacity Factor 60.0%
 Average Available Gen 1340.3 GWh
 Generation Assumed 883.5 GWh
 Life of Infrastructure 30 Years

Capital Cost

2010 Capital Cost \$ 208,157,000
 Relevant Index CCCT Plant Construction
 AFUDC 7.53%

Cost		Distribution	2010	2025	AFUDC	Total
Year -4	2021					
Year -3	2022					
Year -2	2023	13.7%	\$ 28,326,821	\$ 35,438,853	\$ 1,334,198	\$ 36,771,051
Year -1	2024	53.4%	\$ 110,860,928	\$ 141,458,542	\$ 8,094,774	\$ 149,553,316
Year 0	2025	32.9%	\$ 66,969,152	\$ 87,232,895	\$ 17,314,543	\$ 104,547,440

O&M Cost

2010
 Fixed 9,220 \$/MW
 Variable 5.32 \$/MWh
 Escalation 2.8%

Year	Life Year	Investment	Energy Sales	Operating Cost	Fuel Cost	Interest	Cash Flow	Cumulative Cash Flow
		(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
2010						0	0	0
2011						0	0	0
2012						0	0	0
2013						0	0	0
2014						0	0	0
2015						0	0	0
2016						0	0	0
2017						0	0	0
2018						0	0	0
2019						0	0	0
2020						0	0	0
2021						0	0	0
2022						0	0	0
2023		36,771,051				0	-36,771,051	-36,771,051
2024		149,553,316				0	-149,553,316	-186,324,367
2025	0	104,547,440				0	-104,547,440	-290,871,807
2026	1		298,066,590	9,832,650	259,184,642	0	29,049,299	-261,822,508
2027	2		304,027,922	10,107,964	264,020,176	0	29,899,782	-231,922,726
2028	3		310,108,481	10,390,887	269,822,617	0	29,894,677	-202,028,049
2029	4		316,310,650	10,681,935	275,825,458	0	30,003,257	-172,024,792
2030	5		322,636,863	10,981,029	280,460,993	0	31,194,842	-140,829,950
2031	6		329,089,601	11,288,498	286,263,634	0	31,537,489	-109,292,461
2032	7		335,671,393	11,604,575	292,068,275	0	32,000,542	-77,291,939
2033	8		342,384,820	11,929,504	297,868,916	0	32,586,400	-44,705,538
2034	9		349,232,517	12,263,630	303,671,568	0	33,297,430	-11,408,109
2035	10		356,217,167	12,606,908	309,474,199	0	34,136,060	22,727,951
2036	11		363,341,511	12,959,902	316,243,947	0	34,137,662	56,865,613
2037	12		370,606,341	13,322,779	322,046,588	0	35,238,973	92,104,586
2038	13		378,020,608	13,695,817	328,816,336	0	35,508,354	127,612,940
2039	14		385,580,918	14,079,300	335,586,084	0	35,915,533	163,528,474
2040	15		393,292,536	14,473,620	342,355,833	0	36,463,183	199,991,657
2041	16		401,169,387	14,878,779	349,125,581	0	37,154,027	237,145,684
2042	17		409,181,554	15,295,385	355,895,329	0	37,960,841	275,136,525
2043	18		417,365,186	15,723,655	362,665,077	0	38,976,453	314,112,979
2044	19		425,712,489	16,163,918	370,401,932	0	39,146,640	353,259,618
2045	20		434,226,739	16,616,507	378,138,787	0	39,471,445	392,731,063
2046	21		442,911,274	17,081,770	385,875,642	0	39,953,862	432,684,925
2047	22		451,769,499	17,560,059	393,612,497	0	40,596,943	473,281,869
2048	23		460,804,889	18,051,741	401,349,352	0	41,403,797	514,685,666
2049	24		470,020,987	18,557,190	409,086,207	0	42,377,591	557,063,257
2050	25		479,421,407	19,076,791	416,823,062	0	43,521,554	600,584,811
2051	26		489,009,835	19,610,941	425,527,023	0	43,871,870	644,456,681
2052	27		498,790,032	20,160,047	434,230,985	0	44,398,999	688,855,680
2053	28		508,765,832	20,724,529	442,934,947	0	45,106,356	733,962,037
2054	29		518,941,149	21,304,816	451,638,909	0	45,997,424	779,959,461
2055	30		529,319,972	21,901,350	460,342,871	0	47,075,751	827,035,212
2056						0	0	827,035,212
2057						0	0	827,035,212
2058						0	0	827,035,212
2059						0	0	827,035,212
2060						0	0	827,035,212
2061						0	0	827,035,212
2062						0	0	827,035,212
2063						0	0	827,035,212
2064						0	0	827,035,212
2065						0	0	827,035,212
2066						0	0	827,035,212
2067						0	0	827,035,212

M:\1103\00365\02A\Data\Cost Tables\Financial Analysis - BXP2011-11-01.xlsm\170MW CCCT (60%CF)

REV	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D
0	08SEP11	ISSUED WITH REPORT 303-1101-1	BXP	SRM	JPH

TABLE 5.5

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVESHIGH LEVEL REVIEW REPORT
BASIC FINANCIAL ANALYSIS - 50 MW CT

Print: 11/11 16:52

Year of Development		2025				
Financial				Analysis		
Interest Rate		0.0%		Internal Rate of Return	10.5%	
Discount rate		8.0%				
2010 Energy Sale		276.0	\$/MWh			
Energy Sale Escalation		2.0%				
Asset		Greenfield CCCT				
Installed Capacity		50	MW			
Capacity Factor		90.0%				
Average Available Gen		394.2	GWh			
Generation Assumed		394.2	GWh			
Life of Infrastructure		25	Years			
Capital Cost						
2010 Capital Cost		\$ 65,127,000				
Relevant Index		Combustion Turbine Plant Construction				
AFUDC		7.53%				
Cost						
		Distribution	2010	2025	AFUDC	Total
Year -4	2021					
Year -3	2022					
Year -2	2023	1.0%	\$ 682,351	\$ 858,397	\$ 32,319	\$ 890,716
Year -1	2024	20.7%	\$ 17,418,566	\$ 22,348,020	\$ 908,474	\$ 23,256,494
Year 0	2025	72.2%	\$ 47,036,083	\$ 61,570,293	\$ 4,136,404	\$ 65,706,637
O&M Cost		2010	2010			
Fixed		9,220	\$/MW	481,000		
Variable		5.32	\$/MWh	2,097,144		
Escalation		2.8%				

Year	Life Year	Investment	Energy Sales	Operating Cost	Fuel Cost	Interest	Cash Flow	Cumulative Cash Flow
		(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
2010						0	0	0
2011						0	0	0
2012						0	0	0
2013						0	0	0
2014						0	0	0
2015						0	0	0
2016						0	0	0
2017						0	0	0
2018						0	0	0
2019						0	0	0
2020						0	0	0
2021						0	0	0
2022						0	0	0
2023		890,716				0	-890,716	-890,716
2024		23,256,494				0	-23,256,494	-24,147,210
2025	0	65,706,637				0	-65,706,637	-89,863,847
2026	1		149,357,986	3,979,375	135,999,666	0	9,378,947	-80,474,900
2027	2		152,345,146	4,090,797	138,536,972	0	9,717,377	-70,757,523
2028	3		155,392,049	4,205,339	141,581,740	0	9,604,969	-61,152,553
2029	4		158,499,890	4,323,089	144,626,509	0	9,550,292	-51,602,261
2030	5		161,669,888	4,444,135	147,163,816	0	10,061,938	-41,540,325
2031	6		164,903,268	4,568,571	150,208,585	0	10,126,130	-31,414,195
2032	7		168,201,351	4,696,491	153,253,354	0	10,251,507	-21,162,689
2033	8		171,565,378	4,827,903	156,298,122	0	10,439,283	-10,723,425
2034	9		174,999,688	4,963,177	159,342,891	0	10,690,619	-32,807
2035	10		178,496,620	5,102,146	162,387,659	0	11,006,815	10,974,008
2036	11		182,066,552	5,245,006	165,939,889	0	10,881,657	21,855,665
2037	12		185,707,883	5,391,866	168,984,658	0	11,331,359	33,187,024
2038	13		189,422,041	5,542,838	172,536,888	0	11,342,315	44,529,339
2039	14		193,210,482	5,698,036	176,089,118	0	11,423,326	55,952,665
2040	15		197,074,691	5,857,583	179,841,348	0	11,575,760	67,528,425
2041	16		201,016,185	6,021,595	183,193,578	0	11,801,012	79,329,437
2042	17		205,036,509	6,190,200	186,745,808	0	12,100,501	91,429,938
2043	18		209,137,239	6,363,525	190,298,038	0	12,475,675	103,905,613
2044	19		213,319,984	6,541,704	194,357,730	0	12,420,550	116,326,163
2045	20		217,586,383	6,724,872	198,417,421	0	12,444,090	128,770,254
2046	21		221,939,111	6,913,168	202,477,113	0	12,547,830	141,318,084
2047	22		226,376,873	7,106,737	206,536,804	0	12,733,332	154,051,416
2048	23		230,904,411	7,305,725	210,596,496	0	13,002,190	167,053,606
2049	24		235,522,499	7,510,286	214,656,187	0	13,356,025	180,409,632
2050	25		240,232,949	7,720,574	218,715,879	0	13,796,497	194,206,129
2051						0	0	194,206,129
2052						0	0	194,206,129
2053						0	0	194,206,129
2054						0	0	194,206,129
2055						0	0	194,206,129
2056						0	0	194,206,129
2057						0	0	194,206,129
2058						0	0	194,206,129
2059						0	0	194,206,129
2060						0	0	194,206,129
2061						0	0	194,206,129
2062						0	0	194,206,129
2063						0	0	194,206,129
2064						0	0	194,206,129
2065						0	0	194,206,129
2066						0	0	194,206,129
2067						0	0	194,206,129

M:\1103\00365\02\A\Cost Tables\Financial Analysis - BXF2011-11-01.xlsm\50MW CT

REV	DATE	DESCRIPTION	PREP	CHKD	APPD
0		ISSUED WITH REPORT 303-11/01-1			

TABLE 5.6

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVESHIGH LEVEL REVIEW REPORT
BASIC FINANCIAL ANALYSIS - 50 MW CT - CAPACITY PAYMENT

Print: 11/11 16:52

Year of Development	2025					
Financial			Analysis			
Interest Rate	0.0%		Internal Rate of Return	9.0%		
Discount rate	8.0%					
2010 Energy Sale	300.0 \$/MWh					
Capacity Payment	130,000 \$/MW					
Energy Sale Escalation I	2.0%					
Asset	Greenfield CCCT					
Installed Capacity	30 MW					
Capacity Factor	2.0%					
Average Available Gen	304.2 GWh					
Generation Assumed	8.3 GWh					
Life of Infrastructure	25 Years					
Capital Cost						
2010 Capital Cost	\$ 65,137,000					
Relevant Index	Combustion Turbine Plant Construction					
AFUDC	7.53%					
Cost						
	Distribution	2010	2025	AFUDC	Total	
Year -4	2021					
Year -3	2022					
Year -2	2023	1.0%	\$ 682,351	\$ 658,307	\$ 32,319	\$ 890,716
Year -1	2024	26.7%	\$ 17,418,566	\$ 22,348,020	\$ 906,474	\$ 23,256,494
Year 0	2025	72.2%	\$ 47,036,083	\$ 61,570,233	\$ 4,138,404	\$ 65,706,637
O&M Cost		2010	2010			
Fixed		9,220 \$/MW	461,000			
Variable		5.32 \$/MWh	46,603			
Escalation		2.6%				

Year	Life Year	Investment	Energy and Capacity Sales	Operating Cost	Fuel Cost	Interest	Cash Flow	Cumulative Cash Flow
		(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
2010						0	0	0
2011						0	0	0
2012						0	0	0
2013						0	0	0
2014						0	0	0
2015						0	0	0
2016						0	0	0
2017						0	0	0
2018						0	0	0
2019						0	0	0
2020						0	0	0
2021						0	0	0
2022						0	0	0
2023		890,716				0	-890,716	-890,716
2024		23,256,494				0	-23,256,494	-24,147,210
2025		65,706,637				0	-65,706,637	-89,853,847
2026	0		12,530,788	789,613	3,022,215	0	8,718,960	-81,134,887
2027	1		12,781,404	811,722	3,078,599	0	8,891,082	-72,243,804
2028	2		13,037,032	834,450	3,146,261	0	9,056,321	-63,187,484
2029	3		13,297,772	857,815	3,213,922	0	9,228,035	-53,961,449
2030	4		13,563,728	881,834	3,270,307	0	9,411,587	-44,549,861
2031	5		13,835,002	906,525	3,337,989	0	9,590,609	-34,959,253
2032	6		14,111,702	931,908	3,405,630	0	9,774,165	-25,185,088
2033	7		14,393,936	958,001	3,473,282	0	9,962,644	-15,222,444
2034	8		14,681,815	984,825	3,540,953	0	10,156,037	-5,066,407
2035	9		14,975,452	1,012,400	3,608,616	0	10,354,437	5,287,630
2036	10		15,274,961	1,040,747	3,687,553	0	10,546,660	15,834,290
2037	11		15,580,480	1,069,888	3,755,215	0	10,755,357	26,589,647
2038	12		15,892,089	1,099,845	3,834,163	0	10,958,071	37,548,017
2039	13		16,209,910	1,130,641	3,913,092	0	11,166,178	48,714,195
2040	14		16,534,109	1,162,299	3,992,030	0	11,379,780	60,093,975
2041	15		16,864,791	1,194,843	4,070,966	0	11,598,979	71,692,954
2042	16		17,202,067	1,228,299	4,149,907	0	11,823,881	83,516,835
2043	17		17,546,128	1,262,691	4,228,845	0	12,054,592	95,571,427
2044	18		17,897,051	1,298,046	4,318,061	0	12,279,944	107,851,370
2045	19		18,254,992	1,334,392	4,409,278	0	12,511,324	120,362,694
2046	20		18,620,092	1,371,755	4,499,491	0	12,748,846	133,111,540
2047	21		18,992,494	1,410,164	4,588,707	0	12,992,623	146,104,163
2048	22		19,372,343	1,449,648	4,679,922	0	13,242,773	159,346,936
2049	23		19,759,790	1,490,239	4,770,137	0	13,499,414	172,846,350
2050	24		20,154,968	1,531,965	4,860,353	0	13,762,686	186,609,036
2051	25					0	0	186,609,036
2052						0	0	186,609,036
2053						0	0	186,609,036
2054						0	0	186,609,036
2055						0	0	186,609,036
2056						0	0	186,609,036
2057						0	0	186,609,036
2058						0	0	186,609,036
2059						0	0	186,609,036
2060						0	0	186,609,036
2061						0	0	186,609,036
2062						0	0	186,609,036
2063						0	0	186,609,036
2064						0	0	186,609,036
2065						0	0	186,609,036
2066						0	0	186,609,036
2067						0	0	186,609,036

M:\11\03\00365\02A\Data\Cost Tables\Financial Analysis - BXP2011-11-01.xlsm\50MW CT Capacity

REV	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D
0	09/SEP/11	ISSUED WITH REPORT 309-11201-1	BOF	ERM	JPH

TABLE 5.7

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVESHIGH LEVEL REVIEW REPORT
BASIC FINANCIAL ANALYSIS - 25 MW WIND

Print 11/11/11 16:32

Year of Development		2025			
Financial			Analysis		
Interest Rate		0.0%	Internal Rate of Return		10.0%
Discount rate		8.0%			
2010 Energy Sale		60.0 \$/MWh			
Energy Sale Escalation		2.0%			
Asset		Greenfield CCCT			
Installed Capacity		25 MW			
Capacity Factor		40.0%			
Average Available Gen		87.6 GWh			
Generation Assumed		87.6 GWh			
Life of Infrastructure		20 Years			
Capital Cost					
2010 Capital Cost		\$ 59,082,000			
Relevant Index		Increased at 2%			
AFUDC		7.53%			
Cost			Distribution	2010	2025
					AFUDC
					Total
Year -4	2021				
Year -3	2022				
Year -2	2023				
Year -1	2024	33.3%	\$ 19,341,306	\$ 25,520,443	\$ 960,845
Year 0	2025	66.7%	\$ 38,740,694	\$ 52,139,873	\$ 3,957,107
					\$ 26,481,287
					\$ 56,096,981
O&M Cost		2010	2010		
Fixed			0 \$/MW		
			0		
Variable			5.90 \$/MWh		
			516,840		
Escalation			2.5%		

Year	Life Year	Investment	Energy Sales	Operating Cost	Fuel Cost	Interest	Cash Flow	Cumulative Cash Flow
		(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
2010						0	0	0
2011						0	0	0
2012						0	0	0
2013						0	0	0
2014						0	0	0
2015						0	0	0
2016						0	0	0
2017						0	0	0
2018						0	0	0
2019						0	0	0
2020						0	0	0
2021						0	0	0
2022						0	0	0
2023						0	0	0
2024		26,481,287				0	-26,481,287	-26,481,287
2025	0	56,096,981				0	-56,096,981	-82,578,268
2026	1		9,620,482	803,981	0	0	8,816,501	-73,761,767
2027	2		9,812,892	828,493	0	0	8,985,399	-64,775,368
2028	3		10,009,150	849,835	0	0	9,159,515	-55,615,853
2029	4		10,209,333	873,424	0	0	9,335,908	-46,279,944
2030	5		10,413,519	897,880	0	0	9,515,639	-36,764,305
2031	6		10,621,790	923,021	0	0	9,698,769	-27,065,536
2032	7		10,834,226	948,865	0	0	9,885,360	-17,180,176
2033	8		11,050,910	975,434	0	0	10,075,476	-7,104,700
2034	9		11,271,928	1,002,746	0	0	10,269,182	3,184,482
2035	10		11,497,367	1,030,823	0	0	10,466,544	13,631,027
2036	11		11,727,314	1,059,688	0	0	10,667,628	24,298,655
2037	12		11,961,880	1,089,357	0	0	10,872,503	35,171,158
2038	13		12,201,098	1,119,859	0	0	11,081,239	46,252,397
2039	14		12,445,120	1,151,215	0	0	11,293,905	57,546,302
2040	15		12,694,022	1,183,449	0	0	11,510,573	69,056,875
2041	16		12,947,802	1,216,586	0	0	11,731,317	80,788,191
2042	17		13,206,860	1,250,650	0	0	11,956,210	92,744,402
2043	18		13,470,998	1,285,668	0	0	12,185,329	104,929,731
2044	19		13,740,418	1,321,667	0	0	12,418,751	117,348,482
2045	20		14,015,226	1,358,674	0	0	12,656,552	130,005,034
2046						0	0	130,005,034
2047						0	0	130,005,034
2048						0	0	130,005,034
2049						0	0	130,005,034
2050						0	0	130,005,034
2051						0	0	130,005,034
2052						0	0	130,005,034
2053						0	0	130,005,034
2054						0	0	130,005,034
2055						0	0	130,005,034
2056						0	0	130,005,034
2057						0	0	130,005,034
2058						0	0	130,005,034
2059						0	0	130,005,034
2060						0	0	130,005,034
2061						0	0	130,005,034
2062						0	0	130,005,034
2063						0	0	130,005,034
2064						0	0	130,005,034
2065						0	0	130,005,034
2066						0	0	130,005,034
2067						0	0	130,005,034

M:\1103\00365\02\A>Data\Cost Tables\Financial Analysis - BXP2011-11-01.xlsm\25MW Wind

Q	REVISION	DATE	DESCRIPTION	BY	CHKD	APPD
0						

TABLE 5.8

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVESHIGH LEVEL REVIEW REPORT
BASIC FINANCIAL ANALYSIS - 36 MW ISLAND POND HYDRO

Print 11/11/11 10:52

Year of Development 2025

Financial

Interest Rate 0.0%
 Discount rate 8.0%
 2010 Energy Sale 85.0 \$/MWh
 Energy Sale Escalation 2.0%

Analysis

Internal Rate of Return 9.9%

Asset

Greenfield CCCT
 Installed Capacity 36 MW
 Capacity Factor 60.0%
 Average Available Gen 189.2 GWh
 Generation Assumed 189.2 GWh
 Life of Infrastructure 55 Years

Capital Cost

2010 Capital Cost \$ 166,220,000
 Relevant Index Hydraulic Plant Construction
 AFUDC 7.53%

Cost		Distribution	2010	2025	AFUDC	Total
Year -4	2021					
Year -3	2022	3.0%	\$ 4,908,671	\$ 6,000,859	\$ 225,932	\$ 6,226,791
Year -2	2023	24.6%	\$ 40,898,896	\$ 51,000,922	\$ 2,359,062	\$ 53,389,984
Year -1	2024	32.9%	\$ 54,853,299	\$ 69,518,996	\$ 7,106,533	\$ 76,625,530
Year 0	2025	39.6%	\$ 65,781,135	\$ 85,262,192	\$ 13,470,297	\$ 98,762,489

O&M Cost

2010 2010
 Fixed 15,790 \$/MW 568,440
 Variable 0.00 \$/MWh 0
 Escalation 2.0%

Year	Life Year	Investment	Energy Sales	Operating Cost	Fuel Cost	Interest	Cash Flow	Cumulative Cash Flow
		(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
2010						0	0	0
2011						0	0	0
2012						0	0	0
2013						0	0	0
2014						0	0	0
2015						0	0	0
2016						0	0	0
2017						0	0	0
2018						0	0	0
2019						0	0	0
2020						0	0	0
2021						0	0	0
2022		6,226,791				0	-6,226,791	-6,226,791
2023		53,389,984				0	-53,389,984	-59,616,775
2024		76,625,530				0	-76,625,530	-136,242,305
2025	0	98,762,489				0	-98,762,489	-235,004,794
2026	1		22,079,007	884,249	0	0	21,194,758	-213,810,036
2027	2		22,520,587	909,008	0	0	21,611,579	-192,198,457
2028	3		22,070,899	934,460	0	0	22,036,539	-170,161,918
2029	4		23,430,418	960,825	0	0	22,469,794	-147,692,124
2030	5		23,899,027	987,522	0	0	22,911,505	-124,780,620
2031	6		24,377,007	1,015,173	0	0	23,361,834	-101,418,785
2032	7		24,864,548	1,043,598	0	0	23,820,950	-77,597,835
2033	8		25,361,838	1,072,819	0	0	24,289,020	-53,308,815
2034	9		25,869,075	1,102,857	0	0	24,766,218	-28,542,597
2035	10		26,386,457	1,133,737	0	0	25,252,719	-3,289,878
2036	11		26,914,186	1,165,482	0	0	25,748,704	22,458,826
2037	12		27,452,470	1,198,116	0	0	26,254,354	48,713,180
2038	13		28,001,519	1,231,663	0	0	26,769,856	75,483,036
2039	14		28,561,549	1,266,149	0	0	27,295,400	102,778,436
2040	15		29,132,780	1,301,602	0	0	27,831,179	130,609,615
2041	16		29,715,436	1,338,046	0	0	28,377,390	158,987,005
2042	17		30,309,745	1,375,512	0	0	28,934,233	187,921,238
2043	18		30,915,940	1,414,026	0	0	29,501,914	217,423,151
2044	19		31,534,258	1,453,619	0	0	30,080,640	247,503,791
2045	20		32,164,944	1,494,320	0	0	30,670,824	278,174,614
2046	21		32,808,243	1,536,161	0	0	31,272,081	309,446,696
2047	22		33,464,407	1,579,174	0	0	31,885,234	341,331,730
2048	23		34,133,696	1,623,390	0	0	32,510,305	373,842,035
2049	24		34,816,389	1,668,845	0	0	33,147,524	406,989,559
2050	25		35,512,697	1,715,573	0	0	33,797,124	440,786,682
2051	26		36,222,951	1,763,609	0	0	34,459,342	475,246,024
2052	27		36,947,410	1,812,960	0	0	35,134,420	510,380,444
2053	28		37,686,358	1,863,754	0	0	35,822,604	546,203,048
2054	29		38,440,085	1,915,939	0	0	36,524,146	582,727,194
2055	30		39,208,887	1,969,585	0	0	37,239,302	619,966,495
2056	31		39,993,065	2,024,734	0	0	37,968,331	657,934,826
2057	32		40,792,928	2,081,428	0	0	38,711,500	696,646,326
2058	33		41,608,784	2,139,706	0	0	39,469,078	736,115,404
2059	34		42,440,960	2,199,618	0	0	40,241,342	776,356,746
2060	35		43,289,779	2,261,207	0	0	41,028,572	817,385,318
2061	36		44,155,575	2,324,521	0	0	41,831,054	859,216,372
2062	37		45,039,686	2,389,608	0	0	42,649,078	901,865,451
2063	38		45,939,480	2,456,517	0	0	43,482,943	945,348,394
2064	39		46,858,249	2,525,299	0	0	44,332,950	989,681,344
2065	40		47,795,414	2,596,007	0	0	45,199,407	1,034,880,751
2066	41		48,751,323	2,668,696	0	0	46,082,627	1,080,963,378
2067	42		49,726,349	2,743,419	0	0	46,982,930	1,127,946,308

M:\1\03\00365\02A\Data\Cost Tables\Financial Analysis - BXF2011-11-01.xlsm\36MW Hydro

REV	DATE	DESCRIPTION	BY	CHKD	APPD
0	09/SEP/11	ISSUED WITH REPORT 2011-11-01	BKF	BRM	JPH

TABLE 5.9

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVESHIGH LEVEL REVIEW REPORT
BASIC FINANCIAL ANALYSIS - 23 MW PORTLAND CREEK HYDRO

Print 11/11/11 16:52

Year of Development 2025

Financial

Interest Rate 0.0%
 Discount rate 8.0%
 2010 Energy Sale \$8.0 \$/MWh
 Energy Sale Escalation 2.0%

Analysis

Internal Rate of Return 10.0%

Asset

Greenfield CCCT

Installed Capacity 23 MW
 Capacity Factor 70.0%
 Average Available Gen 141.0 GWh
 Generation Assumed 141.0 GWh
 Life of Infrastructure 65 Years

Capital Cost

2010 Capital Cost \$86,908,300
 Relevant Index Hydraulic Plant Construction
 AFUDC 7.33%

Cost		Distribution	2010	2025	AFUDC	Total
Year -4	2021					
Year -3	2022					
Year -2	2023	4.3%	\$ 3,883,469	\$ 4,842,688	\$ 182,327	\$ 5,025,013
Year -1	2024	21.2%	\$ 19,859,946	\$ 25,388,052	\$ 1,334,281	\$ 26,723,333
Year 0	2025	73.5%	\$ 66,065,484	\$ 85,686,933	\$ 5,616,764	\$ 91,303,697

O&M Cost

2010
 Fixed 15,790 \$/MW 383,170
 Variable 0.00 \$/MWh 0
 Escalation 2.9%

Year	Life Year	Investment	Energy Sales	Operating Cost	Fuel Cost	Interest	Cash Flow	Cumulative Cash Flow
		(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
2010						0	0	0
2011						0	0	0
2012						0	0	0
2013						0	0	0
2014						0	0	0
2015						0	0	0
2016						0	0	0
2017						0	0	0
2018						0	0	0
2019						0	0	0
2020						0	0	0
2021						0	0	0
2022						0	0	0
2023		5,025,013				0	-5,025,013	-5,025,013
2024		26,723,333				0	-26,723,333	-31,748,346
2025	0	91,303,697				0	-91,303,697	-123,052,043
2026	1		11,229,508	564,937	0	0	10,664,571	-112,387,472
2027	2		11,454,088	580,765	0	0	10,873,343	-101,514,129
2028	3		11,683,180	597,018	0	0	11,086,164	-90,427,965
2029	4		11,916,844	613,733	0	0	11,303,111	-79,124,854
2030	5		12,155,180	630,917	0	0	11,524,263	-67,600,590
2031	6		12,398,284	648,683	0	0	11,749,701	-55,850,889
2032	7		12,646,250	666,743	0	0	11,979,507	-43,871,382
2033	8		12,899,175	685,412	0	0	12,213,763	-31,657,620
2034	9		13,157,168	704,603	0	0	12,452,556	-19,205,065
2035	10		13,420,301	724,332	0	0	12,696,969	-6,509,095
2036	11		13,688,707	744,614	0	0	12,944,094	6,434,898
2037	12		13,962,482	765,463	0	0	13,197,019	19,632,017
2038	13		14,241,731	786,896	0	0	13,454,636	33,086,653
2039	14		14,526,566	808,929	0	0	13,717,637	46,804,490
2040	15		14,817,097	831,579	0	0	13,986,518	60,790,008
2041	16		15,113,439	854,863	0	0	14,258,576	75,048,584
2042	17		15,415,708	878,799	0	0	14,536,909	89,585,493
2043	18		15,724,022	903,406	0	0	14,820,616	104,406,109
2044	19		16,038,502	928,701	0	0	15,109,802	119,515,911
2045	20		16,359,273	954,705	0	0	15,404,588	134,920,479
2046	21		16,686,458	981,436	0	0	15,705,022	150,625,501
2047	22		17,020,187	1,008,918	0	0	16,011,271	166,636,771
2048	23		17,360,591	1,037,166	0	0	16,323,425	182,960,196
2049	24		17,707,803	1,066,207	0	0	16,641,596	199,601,792
2050	25		18,061,959	1,096,061	0	0	16,965,898	216,567,690
2051	26		18,423,198	1,126,750	0	0	17,296,448	233,864,138
2052	27		18,791,662	1,158,299	0	0	17,633,383	251,497,501
2053	28		19,167,495	1,190,732	0	0	17,976,763	269,474,264
2054	29		19,550,845	1,224,072	0	0	18,326,773	287,801,037
2055	30		19,941,662	1,258,346	0	0	18,683,516	306,484,553
2056	31		20,340,699	1,293,580	0	0	19,047,119	325,531,672
2057	32		20,747,513	1,329,800	0	0	19,417,713	344,949,385
2058	33		21,162,463	1,367,034	0	0	19,795,429	364,744,814
2059	34		21,585,713	1,405,311	0	0	20,180,401	384,925,215
2060	35		22,017,427	1,444,660	0	0	20,572,767	405,497,982
2061	36		22,457,775	1,485,111	0	0	20,972,665	426,470,647
2062	37		22,906,931	1,526,894	0	0	21,380,237	447,850,884
2063	38		23,365,070	1,569,441	0	0	21,795,628	469,646,513
2064	39		23,832,371	1,613,386	0	0	22,218,985	491,865,498
2065	40		24,309,018	1,658,580	0	0	22,650,458	514,515,956
2066	41		24,795,199	1,705,000	0	0	23,090,196	537,606,155
2067	42		25,291,103	1,752,740	0	0	23,538,363	561,144,518

M:\103\00365\02\A\Data\Cost Tables\Financial Analysis - BXF2011-11-01.xlsm\23MW Hydro

REV	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D
0	09SEP11	ISSUED WITH REPORT 303-1191-1	BOF	GRM	JPH

TABLE 5.10

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVESHIGH LEVEL REVIEW REPORT
BASIC FINANCIAL ANALYSIS - 18 MW ROUND POND HYDRO

Print 11/11/11 16:52

Year of Development 2025

Financial

Interest Rate 0.0%
 Discount rate 8.0%
 2010 Energy Sale 98.0 \$/MWh
 Energy Sale Escalation 2.0%

Analysis

Internal Rate of Return 10.0%

Asset

Greenfield CCCT

Installed Capacity 18 MW
 Capacity Factor 94.0%
 Average Available Gen 132.5 GWh
 Generation Assumed 132.3 GWh
 Life of Infrastructure 55 Years

Capital Cost

2010 Capital Cost \$ 1,021,823,354
 Relevant Index Hydraulic Plant Construction
 AFUDC 7.53%

Cost		Distribution	2010	2025	AFUDC	Total
Year -4	2021					
Year -3	2022					
Year -2	2023	8.5%	\$ 12,070,094	\$ 15,051,408	\$ 566,885	\$ 15,618,093
Year -1	2024	17.3%	\$ 67,270,289	\$ 85,567,808	\$ 4,397,670	\$ 89,965,479
Year 0	2025	4.2%	\$ 62,851,971	\$ 81,519,006	\$ 11,019,634	\$ 92,538,639

O&M Cost

2010
 Fixed 15,790 \$/MW 284,220
 Variable 0.00 \$/MWh 0
 Escalation 2.8%

Year	Life Year	Investment	Energy Sales	Operating Cost	Fuel Cost	Interest	Cash Flow	Cumulative Cash Flow
		(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
2010						0	0	0
2011						0	0	0
2012						0	0	0
2013						0	0	0
2014						0	0	0
2015						0	0	0
2016						0	0	0
2017						0	0	0
2018						0	0	0
2019						0	0	0
2020						0	0	0
2021						0	0	0
2022						0	0	0
2023		15,618,093				0	-15,618,093	-15,618,093
2024		89,965,479				0	-89,965,479	-105,583,572
2025	0	92,538,639				0	-92,538,639	-198,122,211
2026	1		18,000,884	442,124	0	0	17,558,760	-180,563,451
2027	2		18,380,902	454,504	0	0	17,908,398	-162,657,053
2028	3		18,726,120	467,230	0	0	18,260,890	-144,386,163
2029	4		19,102,682	480,312	0	0	18,622,370	-125,773,793
2030	5		19,484,738	493,761	0	0	18,990,975	-106,782,818
2031	6		19,874,431	507,586	0	0	19,366,844	-87,415,974
2032	7		20,271,919	521,799	0	0	19,750,120	-67,665,853
2033	8		20,677,358	536,409	0	0	20,140,949	-47,524,905
2034	9		21,090,905	551,429	0	0	20,539,478	-26,985,428
2035	10		21,512,723	566,869	0	0	20,945,654	-6,039,574
2036	11		21,942,977	582,741	0	0	21,360,236	15,320,662
2037	12		22,381,837	599,068	0	0	21,782,779	37,103,442
2038	13		22,829,474	615,831	0	0	22,213,642	59,317,084
2039	14		23,286,063	633,075	0	0	22,652,889	81,970,073
2040	15		23,751,785	650,801	0	0	23,100,984	105,071,058
2041	16		24,226,820	669,023	0	0	23,557,797	128,628,853
2042	17		24,711,357	687,756	0	0	24,023,601	152,652,454
2043	18		25,205,584	707,013	0	0	24,498,571	177,151,025
2044	19		25,709,695	726,809	0	0	24,982,888	202,133,911
2045	20		26,223,889	747,160	0	0	25,476,729	227,610,640
2046	21		26,748,367	768,081	0	0	25,980,287	253,590,927
2047	22		27,283,334	789,587	0	0	26,493,748	280,084,674
2048	23		27,828,001	811,695	0	0	27,017,306	307,101,980
2049	24		28,383,581	834,423	0	0	27,551,159	334,653,139
2050	25		28,953,293	857,787	0	0	28,095,506	362,748,645
2051	26		29,532,359	881,805	0	0	28,650,554	391,399,199
2052	27		30,123,006	906,495	0	0	29,216,511	420,615,710
2053	28		30,725,466	931,877	0	0	29,793,589	450,409,299
2054	29		31,339,975	957,969	0	0	30,382,006	480,791,305
2055	30		31,966,775	984,793	0	0	30,981,982	511,773,287
2056	31		32,606,110	1,012,367	0	0	31,593,743	543,367,030
2057	32		33,258,232	1,040,713	0	0	32,217,519	575,584,550
2058	33		33,923,397	1,069,853	0	0	32,853,544	608,438,094
2059	34		34,601,865	1,099,809	0	0	33,502,058	641,940,150
2060	35		35,293,902	1,130,604	0	0	34,163,299	676,103,449
2061	36		35,999,780	1,162,261	0	0	34,837,520	710,940,969
2062	37		36,719,776	1,194,804	0	0	35,524,972	746,465,941
2063	38		37,454,172	1,228,258	0	0	36,225,913	782,691,854
2064	39		38,203,255	1,262,650	0	0	36,940,605	819,632,459
2065	40		38,967,320	1,298,004	0	0	37,669,316	857,301,776
2066	41		39,746,666	1,334,348	0	0	38,412,319	895,714,094
2067	42		40,541,600	1,371,710	0	0	39,169,890	934,883,985

M:\110300365\02\A\Data\Cost Tables\Financial Analysis - BXF2011-11-01.xlsm]18MW Hydro

0	09SEP11	ISSUED WITH REPORT 303-1191-1	BXF	SRM	JPH
REV	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D

TABLE 5.11

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR
TWO GENERATION EXPANSION ALTERNATIVESHIGH LEVEL REVIEW REPORT
SIMPLIFIED CPW ANALYSIS

Weighted Average Cost Of Capital

8.0%

Print: 11/11/11 10:50

Delta 2,723,872,478

Isolated Island

Labrador Infeed

NPV

9,481,197,482 \$

6,757,325,004 \$

Unit Cost of Renewable Energy

81.0

2010 \$/MWh

(10% IRR)

Unit Cost of Thermal Energy

213.0

2010 \$/MWh

(10% IRR)

Unit Cost of MF and LIL Energy

130.0

2010 \$/MWh

(8% IRR)

Energy Cost Escalation

2%

	Renewable Energy (GWh)	Thermal Energy (GWh)	Total (GWh)	Renewable Energy Cost (\$000)	Thermal Energy Cost (\$000)	Total Cost (\$000)		Renewable Energy (GWh)	Thermal Energy (GWh)	LIL Energy (GWh)	Total (GWh)	Renewable Energy Cost (\$000)	Thermal Energy Cost (\$000)	LIL Costs (\$000)	Total (\$000)
2010	189	1,104	1,293	15,325	268,321	286,233		189	1,104	0	1,293	15,325	268,321	0	286,233
2011	189	1,023	1,212	15,632	253,437	271,492		189	1,023	0	1,212	15,632	253,437	0	271,492
2012	189	1,068	1,257	15,944	269,933	288,391		189	1,068	0	1,257	15,944	269,933	0	288,391
2013	189	1,428	1,617	16,263	368,218	387,715		189	1,428	0	1,617	16,263	368,218	0	387,715
2014	213	1,678	1,891	18,710	441,366	463,859		189	1,702	0	1,892	16,588	447,758	0	468,129
2015	309	1,703	2,012	27,616	457,008	488,649		189	1,823	0	2,012	16,920	489,042	0	509,986
2016	465	1,565	2,030	42,399	428,192	474,650		189	1,840	0	2,029	17,259	503,584	0	524,902
2017	465	1,604	2,069	43,247	447,837	495,222		189	67	1,813	2,069	17,604	18,813	270,674	311,230
2018	473	1,665	2,139	44,909	474,161	523,347		189	68	1,882	2,139	17,956	19,247	286,643	328,123
2019	606	1,603	2,209	58,691	465,523	528,633		189	67	1,953	2,209	18,315	19,573	303,375	345,683
2020	619	1,657	2,276	61,080	490,859	556,490		189	68	2,019	2,276	18,681	20,083	319,934	363,250
2021	745	1,626	2,371	75,062	491,159	570,962		189	67	2,115	2,371	19,055	20,304	341,817	385,918
2022	745	1,723	2,468	76,563	530,999	612,498		189	67	2,212	2,468	19,436	20,741	364,679	409,793
2023	745	1,830	2,575	78,094	575,191	658,435		189	8	2,378	2,575	19,825	2,389	399,939	427,303
2024	745	1,893	2,638	79,656	606,959	691,892		189	2	2,447	2,638	20,221	641	419,774	445,913
2025	745	1,951	2,696	81,249	638,034	724,676		189	2	2,505	2,696	20,626	621	438,335	464,974
2026	745	2,033	2,779	82,874	678,316	766,747		189	2	2,588	2,779	21,038	701	461,771	489,067
2027	745	2,122	2,868	84,532	722,131	812,398		189	2	2,676	2,868	21,459	749	487,134	515,077
2028	745	2,204	2,949	86,234	764,825	856,957		137	3	2,809	2,949	15,838	972	521,608	544,316
2029	745	2,284	3,029	87,947	808,477	902,482		0	4	3,025	3,029	0	1,558	572,853	580,469
2030	745	2,362	3,107	89,706	852,919	948,840		0	5	3,103	3,107	0	1,733	599,339	607,287
2031	745	2,440	3,186	91,500	898,779	996,650		0	5	3,181	3,185	0	1,805	626,675	634,850
2032	745	2,518	3,264	93,330	946,057	1,045,914		0	6	3,258	3,264	0	2,066	654,804	663,398
2033	745	2,596	3,342	95,196	994,905	1,096,785		0	6	3,336	3,342	0	2,261	683,829	692,773
2034	745	2,675	3,420	97,100	1,045,485	1,149,426		0	7	3,414	3,420	0	2,541	713,779	723,154
2035	745	2,745	3,490	99,042	1,094,381	1,200,405		0	7	3,483	3,490	0	2,751	742,935	752,667
2036	745	2,816	3,561	101,023	1,144,978	1,253,123		8	7	3,545	3,561	1,139	2,928	771,195	782,382
2037	745	2,886	3,631	103,044	1,196,995	1,307,301		142	7	3,482	3,631	19,563	2,986	772,728	802,540
2038	745	2,956	3,702	105,104	1,250,676	1,363,184		142	12	3,548	3,702	19,955	4,908	803,121	835,386
2039	745	3,027	3,772	107,207	1,306,113	1,420,863		142	13	3,618	3,772	20,354	5,394	835,251	868,543
2040	745	3,089	3,834	109,351	1,359,701	1,476,720		142	13	3,680	3,834	20,761	5,546	866,602	900,578
2041	745	3,152	3,897	111,538	1,414,910	1,534,242		142	14	3,742	3,897	21,176	6,061	898,730	933,761
2042	745	3,214	3,959	113,768	1,471,876	1,593,563		142	14	3,804	3,960	21,600	6,594	931,845	967,958
2043	745	3,277	4,022	116,044	1,530,647	1,654,735		142	15	3,865	4,022	22,032	7,053	965,875	1,003,004
2044	745	3,339	4,085	118,365	1,591,038	1,717,572		142	16	3,927	4,085	22,472	7,528	1,000,996	1,039,165
2045	745	3,402	4,147	120,732	1,653,232	1,782,258		142	17	3,989	4,147	22,922	8,067	1,037,057	1,076,340
2046	745	3,464	4,210	123,147	1,717,278	1,848,843		142	17	4,051	4,210	23,380	8,575	1,074,186	1,114,561
2047	745	3,527	4,272	125,610	1,783,325	1,917,479		142	19	4,112	4,272	23,848	9,505	1,112,197	1,154,094
2048	745	3,589	4,335	128,139	1,851,069	1,987,877		142	20	4,174	4,335	24,325	10,160	1,151,464	1,194,618
2049	745	3,652	4,397	130,684	1,921,020	2,060,498		142	20	4,235	4,397	24,811	10,731	1,191,828	1,236,165
2050	745	3,707	4,452	133,298	1,988,897	2,131,099		142	21	4,289	4,452	25,307	11,429	1,231,137	1,276,776
2051	745	3,761	4,507	135,964	2,058,557	2,203,534		142	23	4,343	4,507	25,814	12,369	1,271,453	1,318,648
2052	745	3,816	4,562	138,683	2,130,319	2,278,125		142	24	4,396	4,561	26,330	13,174	1,312,919	1,361,546
2053	745	3,871	4,616	141,457	2,204,128	2,354,817		142	25	4,450	4,616	26,856	14,007	1,355,535	1,405,631
2054	745	3,926	4,671	144,286	2,279,863	2,433,491		142	30	4,500	4,671	27,394	17,133	1,398,119	1,451,987
2055	745	3,980	4,726	147,172	2,357,924	2,514,547		142	35	4,550	4,726	27,941	20,438	1,441,896	1,499,726
2056	745	4,035	4,780	150,115	2,438,195	2,597,871		142	39	4,600	4,780	28,500	23,626	1,486,864	1,548,551
2057	745	4,090	4,835	153,117	2,520,672	2,683,460		142	44	4,649	4,835	29,070	27,242	1,532,989	1,598,971
2058	745	4,144	4,890	156,180	2,605,411	2,771,370		142	50	4,699	4,890	29,652	31,119	1,580,263	1,650,812
2059	745	4,199	4,945	159,303	2,692,658	2,861,851		142	55	4,748	4,944	30,245	35,011	1,628,883	1,704,028
2060	745	4,254	4,999	162,489	2,782,288	2,954,776		142	59	4,798	4,999	30,850	38,786	1,678,956	1,758,589
2061	745	4,309	5,054	165,739	2,874,560	3,050,407		142	65	4,847	5,054	31,467	43,364	1,730,059	1,814,998
2062	745	4,363	5,109	169,054	2,969,205	3,148,477		142	70	4,897	5,109	32,096	47,838	1,782,681	1,872,832
2063	745	4,418	5,163	172,435	3,066,556	3,249,318		142	76	4,946	5,163	32,738	52,473	1,836,678	1,932,215
2064	745	4,473	5,218	175,884	3,166,542	3,352,862		142	81	4,996	5,218	33,393	57,062	1,892,197	1,993,088
2065	745	4,528	5,273	179,401	3,269,518	3,459,465		142	90	5,041	5,273	34,060	65,208	1,947,464	2,057,279
2066	745	4,582	5,328	182,989	3,375,126	3,568,770		142	103	5,083	5,328	34,742	76,088	2,002,845	2,124,330
2067	745	4,637	5,382	186,649	3,483,875	3,681,289		142	120	5,121	5,382	35,437	89,781	2,058,377	2,194,359

M:\1\03\00365\02\A\Data\Cost Tables\CPW9.xlsx\NPV Analysis (Simplified)


NOTES:

Notes: 1. Energy distribution from Nalcor Exhibit 100

0	1400111	ISSUED WITH REPORT	BOF	SRM	JPH
REV	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D


M:\103\00385\02\A\Data\Boris Notes\CPW8.xls\Supply Graph - Isolated (2)

Print 13/10/2011 10:11 AM



M:\1103100365102\A\Data\Boris Notes\CPW6.xls\Supply Graph -LIL

Print 13/10/2011 10:09 AM



NOTES:

1. VALUES FROM NALCOR EXHIBIT 100

CONSUMER ADVOCATE FOR NEWFOUNDLAND AND LABRADOR

TWO GENERATION EXPANSION ALTERNATIVES

PROJECTED DEMAND AND CORRESPONDING SUPPLY
INTERCONNECTED ISLAND OPTION

Knight Piésold
CONSULTING

P/A NO.
VA103-365/2

REF. NO.
1


FIGURE 3.2

REV B

0	11OCT11	ISSUED WITH REPORT	BWF	SRM	JPH
REV	DATE	DESCRIPTION	PREPD	CHK'D	APPD

M:\1103\00365\02\A\Data\Cost Tables\Financial Analysis - BXF2011-10-13.xls]Figure 6.1

Print 13/10/2011 3:53 PM

**NOTES:**

1. AFUDC included, but no interest on Capital.
2. 2010 Energy Price Escalated at 2% Annually

CONSUMER ADVOCATE FOR NL

TWO GENERATION EXPANSION ALTERNATIVES

HIGH LEVEL REVIEW
ENERGY COST VS. DEVELOPMENT YEAR

Knight Piésold
 CONSULTING

P/A NO.
 VA303-112/4-1


REF. NO.
 1

FIGURE 5.1REV
0

0	09SEP'11	ISSUED WITH REPORT VA303-112/4-1	BXF	SRM	JPH
REV	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D

M:\1103\00365\02\A\Data\Cost Tables\Fuel Sensitivity.xls]Figure 5.2

Print 02/11/2011 8:56 AM

**NOTES:**

1. Interest during construction included, but no interest on Capital.
2. Weighted Average Cost of Capital 8%.
3. 2010 Energy Price Escalated at 2% Annually.
4. Thermal Energy Cost based on a 170 MW CCCT with 60% Capacity Factor and 2025 Inservice Date and a 10% IRR.
5. Renewable energy cost based on a hydro and wind and 2025 Inservice Date and a 10% IRR.
6. All Capital Cost and Price Escalators as provided by Nalcor.
7. MF and LIL Cost amortized over projected MF and LIL energy consumption.

0	27OCT'11	ISSUED FOR REPORT 303-112/1-1	BXF	SRM	JPH
REV	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D

CONSUMER ADVOCATE FOR NL		
TWO GENERATION EXPANSION ALTERNATIVES		
CUMULATIVE PRESENT WORTH SENSITIVITY ANALYSIS		
Knight Piésold CONSULTING	P/A NO. VA103-365/2-1	REF. NO. 1
	FIGURE 5.2	
		REV 0