



CIMFP Exhibit P-03088

Page 1

Page: 1 of 1

Toll Free: 1-800-563-5471
Accident Reporting: 729-4444

INSPECTION / OFFICER'S REPORT

Reference #: 0671924
Inspection: MAY 30, 2016
MAY 30, 2016

ASTALDI CANADA
HAMILTON RIVER ROAD
GOOSE BAY
NL

Firm #: 600062
WCC #: 2052257
Tel:
Fax:

A0P-1C0

Worksite : Draft Tube Number 2
Location : Muskrat Falls Powerhouse, Goose Bay NL.
Employer Co-Chair : Unknown
Employee Co-Chair : Unknown
Worker Rep/Designate: N/A

Employees :
NIC : 4123
Insp. Time: 4:00PM

REPORT:

Assignment No.

Arrived on site May 30, 2016 with OHS Engineer Kim Bannister to investigate an accident. The OHS Division was informed that concrete formwork and falsework collapsed during a concrete pour. We met with members of the RCMP, NALCOR and Astaldi and visited the area.

A Stop Work Order is issued on all concrete pours on all four draft tubes and associated work until the formwork and falsework are evaluated by a P. Eng licensed to practice in this Province. This evaluation shall be in consultation with the falsework and formwork provider and an Engineering review of all associated drawings and assembly procedures and practice shall be undertaken. The Stop Work Order shall remain in place until lifted by this Division.

Two Directives issued.

Received By: *Chris Fergus*

Date: MAY 30, 2016

Position: *Regional Superintendent*

Time: 7:47PM

Officer's Name: *Aiden Browne*

Browne, Aiden

Kim Bannister

Bannister, Kim

A copy of this inspection/order report must be provided at the earliest possible opportunity to your OHS Committee, Worker Representative or Workplace Designate.



ORDER FORM

Toll Free: 1-800-563-5471

ASTALDI CANADA
HAMILTON RIVER ROAD
GOOSE BAY
NL

A0P-1C0

Firm #: 600062
WCC #: 2052257
Tel :
Fax :
NIC :

TAKE NOTICE THAT YOU ARE TO COMPLY WITH THE FOLLOWING ORDER(S) ISSUED UNDER AUTHORITY OF THE OCCUPATIONAL HEALTH AND SAFETY ACT, REVISED STATUTES OF NEWFOUNDLAND AND LABRADOR 1990, CHAPTER 0-3 AS AMENDED AND REGULATIONS PASSED PURSUANT THERETO.

ORDER: 0671924- 01

ACT: Occupational Health and Safety
27 - 1a -Stop work orders

Where the assistant deputy minister or an officer is of the opinion that work is being carried out in a way that the conditions at the workplace pose an immediate risk to the health and safety of workers engaged in the workplace or other persons at or near the workplace, the assistant deputy minister or officer shall, in writing, order the person at the workplace responsible for the work being carried out to immediately stop all or a portion of the work and to vacate all or a portion of the workplace; and

REGULATION: Part III - General Duties
14 1- General duties of employers

An employer shall ensure, so far as is reasonably practicable, that all buildings, structures, whether permanent or temporary, excavation, machinery, workstations, places of employment and equipment are capable of withstanding the stresses likely to be imposed upon them and of safely performing the functions for which they are used or intended.

TO WIT:

A Stop Work Order is issued on all concrete pours on all four draft tubes and associated work until the formwork and falsework are evaluated by a P. Eng licensed to practice in this Province. This evaluation shall be in consultation with the falsework and formwork provider and an Engineering review of all associated drawings and assembly procedures and practice shall be undertaken. The Stop Work Order shall remain in place until lifted by this Division.

This Order shall be carried out on or before: JUL 31, 2016

A copy of this inspection/order report must be provided at the earliest possible opportunity to your OHS Committee, Worker Representative or Workplace Designate.



ORDER FORM

Toll Free: 1-800-563-5471

ORDER: 0671924- 02

ACT: Occupational Health and Safety
26 - 1e -Powers of investigation

For the purpose of ensuring compliance with the Act or regulations and an order made under either of them, the assistant deputy minister, or an officer may make examinations and conduct investigations that he or she consider necessary in order to determine the cause and particulars of an accident or illness occurring to a worker or self-employed person that appears to the investigator as having been caused as a result of an activity at the workplace.

TO WIT:

The following information shall be provided.

- engineering drawings for the falsework/formwork
- assembly instructions for the falsework/formwork
- inspections/signoffs for the falsework/formwork
- concrete placing procedures
- concrete batch tickets and information on placement rate
- concrete testing records including concrete density
- concrete mix design and any changes made to it during the pour

This Order shall be carried out on or before: JUN 10, 2016

YOU ARE TO NOTIFY THE INSPECTOR IN WRITING UPON COMPLIANCE.
FAILURE TO COMPLY WITH THE ABOVE ORDER(S) IS AN OFFENCE UNDER SECTION 67 OF THE OCCUPATIONAL HEALTH AND SAFETY ACT, RSNL 1990, CHAPTER 0-3 AS AMENDED.

AN ORDER MADE BY AN OFFICER MAY BE APPEALED, IN WRITING, TO THE ASSISTANT DEPUTY MINISTER WITHIN 7 DAYS OF THE ORDER.

Received By: *Chris Paus*
Position: *General Superintendent*
Officer's Name: *Aiden Browne*
Browne, Aiden

Return Address:
P.O. Box 8700
St. John's, NL, A1B 4J6
Fax: (709) 729-3445

Date: MAY 30, 2016
Time: 7:45PM

A copy of this inspection/order report must be provided at the earliest possible opportunity to your OHS Committee, Worker Representative or Workplace Designate.