PUB-Nalcor-15 Muskrat Falls Review

Page 1 of 1

1			
	2	Q.	What is the approximate cost estimate increase to design the overland HVDC line to
	3		a 1-in-150 year return period?
	4		
	5		
	6	A.	Table CA.2 in CAN/CSA-C22.3 No. 60826:06 (please see PUB-Nalcor-14) indicates
	7		that the 1 in 150 year return period scalars are 1.10 and 1.15 over 1 in 50 years
	8		results for wind and ice loading respectively over 1 in 50 year results, and using the
	9		same approach as outlined in PUB-Nalcor-14, this is expected to result in capital

cost increase in the order of \$150 million.

10